Detailed Inventory

Town of Basin

WY5600004C

Date Last Updated: 10/4/2024

Purpose of this worksheet: To provide a customizable format water systems can use to track materials for each service line in their distribution system.

General Instructions: Each row in this worksheet represents one service line connecting the water main to the customer's plumbing. The worksheet includes required and recommended elements; the columns with the aqua shading are required by the LCRR. Systems can customize by adding or deleting columns. Important notes for each column are in Row 12; also see the **Template Instructions** worksheet for detailed instructions. Note that users can freeze panes to enable them to see the headings and notes when entering data. The worksheet includes examples in rows 13 - 20 and is formatted for approximately 10,000 entries.

Location Information				System-Owned Portion									Customer-Owned Portion							Entire Service Line Material Classification	Other Potential Sources of Lead			Additional Information to Assign Tap Monitoring Tiering				Lead Service Line Replacement (LSLR)	
Unique Service Line ID	Location Identifier: Street Address	Location Identifier: Other Location Identifier	Sensitive Population? (Yes/No)	Disadvantaged Neighborhood? (Yes/No)	System-Owned Portion Service Line Material Classification	If Non-Lead in Column G, Was Material Ever Previously Lead?	Service Line Installation Date	Service Line Size	Basis of Material Classification	Was the Service Line Material Field Verified?	If "Yes" Service Line Material Was Field Verified: Describe the Field Verification Method	If "Yes" Service Line Material Was Field Verified: Enter the Date of Field Verification	Notes	Customer-Owned Portion Service Line Material Classification	Service Line Installation Date	Service Line Size	Basis of Material Classification	Was the Service Line Material Field Verified?	If "Yes" Service Line Material Was Field Verified: Describe the Field Verification Method	If "Yes" Service Line Material Was Field Verified: Enter the Date of Field Verification	Notes		Is there a Lead Connector?	Is there Lead Solder in the Service Line?	Describe Other Fittings and Equipment Connected to the Service Line that Contains Lead	Building Type Connected to Service Line	Point-of-Entry or Point-of-Use Treatment Present?	Does the Interior Building Plumbing Contain Copper Pipes with Lead Solder Installed Before Your State's Lead Ban (Generally 1986 - 1988)?	Current LCR Sampling Site?	Date of System-owned LSLR	Date of Customer-owned LSLR
A Unique ID is recommended for each service line.	*Water systems must track addresses of all service lines in their internal inventory. For the publicly accessible version, location identifiers are required for lead and galvanized requiring replacement. If the system does not use addresses for their location identifier, other options could include GPS coordinates, landmark, intersection, block, or other details to specify service line location.*		*Select Yes if sensitive subpopulation, e.g., day care, school, multifamily home. If Yes-Other, describe in the Notes field.*	*Does location meet state affordability guidelines or other measures?*	*Dropdown list includes recommended subclassifications. If "Non-Lead Other", describe in Notes field*	*Select Yes, No, or Don't know. Important for determining if downstream/ customer-owned galvanized service line requires replacement*	*Date, year, or estimated date range when the service line was installed or replaced*	*Diameter in Inches*	*Select option from drop down list. If "Other," describe in the Notes field*	*Select Yes or No*	*Select option from drop down list. If "Other," describe in the Notes field*	*Enter approximate date of field verification or date that the record was updated*	*Can use this field for documenting additional relevant information, including when classification changes.*	*Dropdown list includes recommended subclassifications. If non-lead other, describe in Notes field.*	*Date, year, or estimated date range when the service line was installed or replaced*	*Diameter in inches*	*Select option from drop down list. If "Other," describe in the Notes field*	*Select Yes or No*	*Select option from drop down list. If "Other," describe in the Notes field*	*Enter approximate date of field verification or date that record was updated*	*Can use this field for documenting additional relevant information, including when classification changes.*	*Dropdown list includes four required service line classifications of Lead, Non-lead, Galvanized Requiring Replacement, or Unknown*	*For example, lead gooseneck or pigtail where the water main is connected to the service line*	*Select Yes, No, or Don't Know*	*For example, backflow preventer or meter containing lead*	*Note: This information may be helpful for identifying lead tap monitoring locations.*					
10010	755 N 7th		No	No	Unknown - Unlikely Lead	Don't know	1906	3/4"	Other	No	Other			Non-Lead - Plastic	1906	3/4"	Other	Yes	Other	12/18/2023	Visual inspection at inlet side of meter-Poly Line	Unknown				Single Family Residence	No	Unknown	No		
10020	617 W Zane		No	No	Unknown - Unlikely Lead	Don't know	1984	3/4"	Other	No	Other			Non-Lead - Copper	1984	3/4"	Other	Yes	Other	1/18/2024	Visual inspection at inlet side of meter-Copper Line	Unknown				Single Family Residence	No	Unknown	Yes		
10030	758 N 6th		No	No	Unknown - Unlikely Lead	Don't know	1959	3/4"	Other	No	Other			Non-Lead - Copper	1959	3/4"	Other	Yes	Other	8/10/2024	Visual inspection at inlet side of meter-Copper Line	Unknown				Single Family Residence	No	Unknown	No		
10040	756 N 6th		No	No	Unknown - Unlikely Lead	Don't know	1900	3/4"	Other	No	Other			Non-Lead - Copper	1900	3/4"	Other	Yes	Other	12/19/2023	Visual inspection at inlet side of meter-Copper Line	Unknown				Single Family Residence	No	Unknown	No		
10050	610 Richardson		No	No	Unknown - Unlikely Lead	Don't know	1970	3/4"	Other	No	Other			Non-Lead - Copper	1970	3/4"	Other	Yes	Other	12/21/2023	Visual inspection at inlet side of meter-Copper Line	Unknown				Single Family Residence	No	Unknown	No		
10060	620 Richardson		No	No	Unknown - Unlikely Lead	Don't know	1960	3/4"	Other	No	Other			Non-Lead - Plastic	1960	3/4"	Other	Yes	Other		Customer Verification from the Water Line Survey-Plastic Pipe	Unknown				Single Family Residence	No	Unknown	No		
10070	756 North 7th		No	No	Unknown - Unlikely Lead	Don't know	1916	3/4"	Other	No	Other			Non-Lead - Copper	1916	3/4"	Other	Yes	Other	9/9/2024	Visual inspection at inlet side of meter-Copper Line	Unknown				Single Family Residence	No	Unknown	No		
10080	850 North 7th		No	No	Unknown - Unlikely Lead	Don't know	1976	3/4"	Other	No	Other			Non-Lead - Copper	1976	3/4"	Other	Yes	Other	3/26/2024	Visual inspection at inlet side of meter-Copper Line	Unknown				Single Family Residence	No	Unknown	No		
10100	618 W Zane		No	No	Non-Lead - Plastic	No	2010	3/4"	Other	No	Other			Non-Lead - Plastic	2010	3/4"	Other	Yes	Other	9/3/2024	Visual inspection at inlet side of meter-Poly Line	Non-Lead				Single Family Residence	No	No	No		
10110	853 N 7th		No	No	Non-Lead - Plastic	No	2012	3/4"	Other	No	Other			Non-Lead - Plastic	2012	3/4"	Other	Yes	Other	3/19/2024	Visual inspection at inlet side of meter-Poly Line	Non-Lead				Single Family Residence	No	No	No		
10120	607 Rue		No	No	Non-Lead - Plastic	No	2016	3/4"	Installation date after lead ban	No	Other			Non-Lead - Plastic	2016	3/4"	Installation date after lead ban	No	Other	1/12/2024		Non-Lead				Single Family Residence	No	No	No		
10131	609 Rue		No	No	Unknown - Unlikely Lead	Don't know	1982	3/4"	Other	No	Other			Non-Lead - Copper	1982	3/4"	Other	Yes	Other	1/12/2024	Visual inspection at inlet side of meter-Copper Line	Unknown				Other	Yes	Yes	Yes		
10140	860 N 7th		No	No	Unknown - Unlikely Lead	Don't know	1976	3/4"	Other	No	Other			Non-Lead - Copper	1976	3/4"	Other	Yes	Other	5/27/2024	Visual inspection at inlet side of meter-Copper Line	Unknown				Single Family Residence	No	Yes	No		
10142	858 N 7th		No	No	Non-Lead - Plastic	No	2014	3/4"	Other	No	Other			Non-Lead - Plastic	2014	3/4"	Other	Yes	Other	3/18/2024	Visual inspection at inlet side of meter-Poly Line	Non-Lead				Single Family Residence	No	No	No		
10143	858 1/2 North 7th		No	No	Non-Lead - Plastic	No	2015	3/4"	Other	No	Other			Non-Lead - Plastic	2015	3/4"	Other	Yes	Other	1/22/2024	Visual inspection at inlet side of meter-Poly Line	Non-Lead				Building	No	No	No		
10150	950 N 7th		No	No	Unknown - Unlikely Lead	Don't know	1994	3/4"	Other	No	Other			Non-Lead - Copper	1994	3/4"	Other	Yes	Other	1/16/2024	Visual inspection at inlet side of meter-Copper Line	Unknown				Single Family Residence	No	No	No		
10160	960 N 7th		No	No	Unknown - Unlikely Lead	Don't know	1940	3/4"	Other	No	Other			Non-Lead - Copper	1940	3/4"	Other	Yes	Other	12/19/2023	Visual inspection at inlet side of meter-Copper Line	Unknown				Single Family Residence	No	Yes	No		
10170	610 Hart		No	No	Unknown - Unlikely Lead	Don't know	1904	3/4"	Other	No	Other			Non-Lead - Copper	1904	3/4"	Other	Yes	Other	12/21/2023	Visual inspection at inlet side of meter-Copper Line	Unknown				Single Family Residence	No	Yes	Yes		
10177	606 Hart		No	No	Unknown - Unlikely Lead	Don't know	2006	3/4"	Other	No	Other			Non-Lead - Plastic	2006	3/4"	Other	Yes	Other	12/29/2023	Visual inspection at inlet side of meter-Poly Line	Unknown				Single Family Residence	No	No	No		
10180	611 W Hart		No	No	Unknown - Unlikely Lead	Don't know	1981	3/4"	Other	No	Other			Non-Lead - Copper	1981	3/4"	Other	Yes	Other	12/18/2023	Visual inspection at inlet side of meter-Copper Line	Unknown				Single Family Residence	No	Yes	No		
10210	960 N 6th		No	No	Unknown - Unlikely Lead	Don't know	1981	3/4"	Other	No	Other			Non-Lead - Copper	1981	3/4"	Other	Yes	Other	2/21/2024	Visual inspection at inlet side of meter-Copper Line	Unknown				Single Family Residence	No	Yes	No		
10215	958 N 6th		No	No	Unknown - Unlikely Lead	Don't know	2005	3/4"	Other	No	Other			Non-Lead - Plastic	2005	3/4"	Installation date after lead ban	Yes	Other	4/11/2023	Visual inspection at inlet side of meter-Poly Line	Unknown				Other	No	Unknown	No		
10220	965 N 6th		No	No	Unknown - Unlikely Lead	Don't know	1999	3/4"	Installation date after lead ban	No	Other			Non-Lead - Plastic	1999	3/4"	Installation date after lead ban					Unknown				Other	No	No	No		
10225	610 Rue Ave.		No	No	Unknown - Unlikely Lead	Don't know	2007	3/4"	Other	No	Other			Non-Lead - Plastic	2007	3/4"	Other	Yes	Other	3/14/2024	Visual inspection at inlet side of meter-Poly Line	Unknown				Single Family Residence	No	No	No		
10230	955 N 7th		No	No	Unknown - Unlikely Lead	Don't know	1970	3/4"	Other	No	Other			Non-Lead - Copper	1970	3/4"	Other	Yes	Other	2/7/2023	Visual inspection at inlet side of meter-Copper Line	Unknown				Single Family Residence	No	Yes	No		
10240	957 N 7th		No	No	Unknown - Unlikely Lead	Don't know	1970	3/4"	Other	No	Other			Non-Lead - Copper	1970	3/4"	Other	Yes	Other	12/27/2023	Visual inspection at inlet side of meter-Copper Line	Unknown				Single Family Residence	No	Yes	No		
10250	862 N 6th		No	No	Unknown - Unlikely Lead	Don't know	1978	3/4"	Other	No	Other			Non-Lead - Copper	1978	3/4"	Other	Yes	Other	2/2/2024	Visual inspection at inlet side of meter-Copper Line	Unknown				Single Family Residence	No	Yes	No		
10255	854 N 6th		No	No	Unknown - Unlikely Lead	Don't know	2001	3/4"	Installation date after lead ban	No	Other			Non-Lead - Plastic	2001	3/4"	Installation date after lead ban					Unknown				Building	No	No	No		
10260	850 N 6th		No	No	Unknown - Unlikely Lead	Don't know	1997	3/4"	Installation date after lead ban	No	Other			Non-Lead - Plastic	1997	3/4"	Installation date after lead ban	Yes	Other	3/20/2024	Visual inspection at inlet side of meter-Poly Line	Unknown				Single Family Residence	No	Yes	No		
10300	953 N 8th		No	No	Unknown - Unlikely Lead	Don't know	1984	3/4"	Other	Yes	Visual inspection at the meter pit	9/6/2024	Changed out the water meter. Visual inspection at that time. Poly Pipe Material	Non-Lead - Plastic	1984	3/4"	Other	Yes	Other	9/6/2024	Visual inspection at the meter pit-Poly Line	Unknown				Single Family Residence	No	Unknown	No		
10460	756 N 8th		No	No	Unknown - Unlikely Lead	Don't know	2002	3/4"	Other	No	Other			Non-Lead - Plastic	2002	3/4"	Other	Yes	Other	2/28/2023	Visual inspection at inlet side of meter-Poly Line	Unknown				Single Family Residence	No	No	No		
10510	854 N 8th		No	No	Unknown - Unlikely Lead	Don't know	2000	3/4"	Other	No	Other			Non-Lead - Plastic	2000	3/4"	Other	Yes	Other	7/3/2024	Visual inspection at inlet side of meter-Poly Line	Unknown				Single Family Residence	No	No	No		
10517	960 N 8th		No	No	Unknown - Unlikely Lead	Don't know	1967	3/4"	Other	No	Other			Non-Lead - Plastic	1967	3/4"	Other	Yes	Other	9/6/2024	Visual inspection at the meter pit-Poly Line	Unknown				Single Family Residence	No	Unknown	No		
10519	35 Highway 30		No	No	Unknown - Unlikely Lead	Don't know	1976	3/4"	Other	No	Other			Non-Lead - Copper	1976	3/4"	Other	Yes	Other	2/6/2024	Visual inspection at the inlet side of the meter-Copper Line	Unknown				Single Family Residence	No	Unknown	No		
10521	4155 Golf Course Road		No	No	Non-Lead - Plastic	Don't know	2004	3/4"	Other	No	Other			Non-Lead - Copper	2004	3/4"	Other	Yes	Other	12/29/2023	Visual inspection at the inlet side of the meter-Copper Line	Non-Lead				Single Family Residence	No	No	No		
10522	4169 Golf Course Road		No	No	Unknown - Unlikely Lead	Don't know	1978	3/4"	Other	No	Other			Non-Lead - Copper	1978	3/4"	Other	Yes	Other	2/6/2024	Visual inspection at the inlet side of the meter-Copper Line	Unknown				Single Family Residence	No	Unknown	No		
10530	4141 Golf Course Road		No	No	Unknown - Unlikely Lead	Don't know	1942	3/4"	Other	No	Other			Non-Lead - Copper	1942	3/4"	Other	Yes	Other	6/21/2024	Visual inspection at the inlet side of the meter-Copper Line	Unknown				Single Family Residence	No	Unknown	No		
10640	25 Highway 30		No	No	Unknown - Unlikely Lead	Don't know	1947	3/4"	Other	No	Other			Unknown - Unlikely Lead	1947	3/4"	Other	Yes	Other	3/19/2024	Visual inspection at the inlet side of the meter-Copper Line	Unknown				Single Family Residence	No	Unknown	No		
10630	49 Highway 30		No	No	Unknown - Unlikely Lead	Don't know	1974	3/4"	Other	No	Other			Unknown - Unlikely Lead	1974	3/4"	Other	Yes	Other	3/29/2024	Visual inspection at the inlet side of the meter-Copper Line	Unknown				Single Family Residence	No	Unknown	No		
10625	47 Highway 30		No	No	Unknown - Unlikely Lead	Don't know	1979	3/4"	Other	No	Other			Non-Lead - Plastic	1979	3/4"	Other	Yes	Other	8/27/2024	Visual inspection at the inlet side of the meter-Poly Line	Unknown				Single Family Residence	No	Unknown	No		
10650	156 N 8th		No	No	Unknown - Unlikely Lead	Don't know	1978	3/4"	Other	No	Other			Non-Lead - Copper	1978	3/4"	Other	Yes	Other	1/22/2024	Visual inspection at the inlet side of the meter-Copper Line	Unknown				Single Family Residence	No	Unknown	No		
10660	192 N 8th		No	No	Unknown - Unlikely Lead	Don't know	1982	3/4"	Other	No	Other			Non-Lead - Copper	1982	3/4"	Other	Yes	Other	3/7/2024	Visual inspection at the inlet side of the meter-Copper Line	Unknown				Building	No	Unknown	No		
10710	252 N 8th		No	No	Unknown - Unlikely Lead	Don't know	1976	3/4"	Other	No	Other			Non-Lead - Copper	1976	3/4"	Other	Yes	Other	12/19/2024	Visual inspection at the inlet side of the meter-Copper Line	Unknown				Single Family Residence	No	Unknown	No		
10721	258 N 8th		No	No	Unknown - Unlikely Lead	Don't know	1920	3/4"	Other	No	Other			Non-Lead - Copper	1920	3/4"	Other	Yes	Other	12/20/2024	Visual inspection at the inlet side of the meter-Copper Line	Unknown				Single Family Residence	No	Unknown	No		
10723	815 West E Apt 1		No	No	Non-Lead - Plastic	No	2008	3/4"	Installation date after lead ban	No	Other			Non-Lead - Copper	2008	3/4"	Installation date after lead ban	Yes	Other	12/6/2023	Visual inspection at the inlet side of the meter-Copper Line	Non-Lead				Multiple Family Residence	No	No	No		
10724	815 West E Apt 2		No	No	Non-Lead - Plastic	No	2008	3/4"	Installation date after lead ban	No	Other			Non-Lead - Copper	2008	3/4"	Installation date after lead ban	Yes	Other	12/6/2023	Visual inspection at the inlet side of the meter-Copper Line	Non-Lead				Multiple Family Residence	No	No	No		
10725	815 West E Apt 3		No	No	Non-Lead - Plastic	No	2008	3/4"	Installation date after lead ban	No	Other			Non-Lead - Copper	2008	3/4"	Installation date after lead ban	Yes	Other	12/6/2023	Visual inspection at the inlet side of the meter-Copper Line	Non-Lead				Multiple Family Residence	No	No	No		
10726	815 West E Apt 4		No	No	Non-Lead - Plastic	No	2008	3/4"	Installation date after lead ban	No	Other			Non-Lead - Copper	2008	3/4"	Installation date after lead ban	Yes	Other	12/6/2023	Visual inspection at the inlet side of the meter-Copper Line	Non-Lead				Multiple Family Residence	No	No	No		
10727	815 West E Apt 5		No	No	Non-Lead - Plastic	No	2008	3/4"	Installation date after lead ban	No	Other			Non-Lead - Copper	2008	3/4"	Installation date after lead ban	Yes	Other	12/6/2023	Visual inspection at the inlet side of the meter-Copper Line	Non-Lead				Multiple Family Residence	No	No	No		
10728	815 West E Apt 6		No	No	Non-Lead - Plastic	No	2008	3/4"	Installation date after lead ban	No	Other			Non-Lead - Copper	2008	3/4"	Installation date after lead ban	Yes	Other	12/6/2023	Visual inspection at the inlet side of the meter-Copper Line	Non-Lead				Multiple Family Residence	No	No	No		
10729	815 West E Apt 7		No	No	Non-Lead - Plastic	No	2008	3/4"	Installation date after lead ban	No	Other			Non-Lead - Copper	2008	3/4"	Installation date after lead ban	Yes	Other	12/6/2023	Visual inspection at the inlet side of the meter-Copper Line	Non-Lead				Multiple Family Residence	No	No	No		
10730	815 West E Apt 8		No	No	Non-Lead - Plastic	No	2008	3/4"	Installation date after lead ban	No	Other			Non-Lead - Copper	2008	3/4"	Installation date after lead ban	Yes	Other	12/6/2023	Visual inspection at the inlet side of the meter-Copper Line	Non-Lead				Multiple Family Residence	No	No	No		
10732	817 West E Apt 1		No	No	Non-Lead - Plastic	No	2008	3/4"	Installation date after lead ban	No	Other			Non-Lead - Copper	2008	3/4"	Installation date after lead ban	Yes	Other	12/6/2023	Visual inspection at the inlet side of the meter-Copper Line	Non-Lead				Multiple Family Residence	No	No	No		

10733	817 West E Apt 2	No	No	Non-Lead - Plastic	No	2008	3/4"	Installation date after lead ban	No	Other		Non-Lead - Copper	2008	3/4"	Installation date after lead ban	Yes	Other	12/6/2023	Visual Inspection at the inlet side of the meter- Copper Line	Non-Lead	Multiple Family Residence	No	No	No	
10734	817 West E Apt 3	No	No	Non-Lead - Plastic	No	2008	3/4"	Installation date after lead ban	No	Other		Non-Lead - Copper	2008	3/4"	Installation date after lead ban	Yes	Other	12/6/2023	Visual Inspection at the inlet side of the meter- Copper Line	Non-Lead	Multiple Family Residence	No	No	No	
10735	817 West E Apt 4	No	No	Non-Lead - Plastic	No	2008	3/4"	Installation date after lead ban	No	Other		Non-Lead - Copper	2008	3/4"	Installation date after lead ban	Yes	Other	12/6/2023	Visual Inspection at the inlet side of the meter- Copper Line	Non-Lead	Multiple Family Residence	No	No	No	
10736	817 West E Apt 5	No	No	Non-Lead - Plastic	No	2008	3/4"	Installation date after lead ban	No	Other		Non-Lead - Copper	2008	3/4"	Installation date after lead ban	Yes	Other	12/6/2023	Visual Inspection at the inlet side of the meter- Copper Line	Non-Lead	Multiple Family Residence	No	No	No	
10737	817 West E Apt 6	No	No	Non-Lead - Plastic	No	2008	3/4"	Installation date after lead ban	No	Other		Non-Lead - Copper	2008	3/4"	Installation date after lead ban	Yes	Other	12/6/2023	Visual Inspection at the inlet side of the meter- Copper Line	Non-Lead	Multiple Family Residence	No	No	No	
10738	817 West E Apt 7	No	No	Non-Lead - Plastic	No	2008	3/4"	Installation date after lead ban	No	Other		Non-Lead - Copper	2008	3/4"	Installation date after lead ban	Yes	Other	12/6/2023	Visual Inspection at the inlet side of the meter- Copper Line	Non-Lead	Multiple Family Residence	No	No	No	
10739	817 West E Apt 8	No	No	Non-Lead - Plastic	No	2008	3/4"	Installation date after lead ban	No	Other		Non-Lead - Copper	2008	3/4"	Installation date after lead ban	Yes	Other	12/6/2023	Visual Inspection at the inlet side of the meter- Copper Line	Non-Lead	Multiple Family Residence	No	No	No	
10749	352 N 8th	No	No	Unknown - Unlikely Lead	Don't know	1980	3/4"	Other	No	Other		Non-Lead - Plastic	1980	3/4"	Other	Yes	Other	12/19/2023	Visual Inspection at the inlet side of the meter- Poly Line	Unknown	Single Family Residence	No	Unknown	No	
10750	354 N 8th	No	No	Unknown - Unlikely Lead	Don't know	1980	3/4"	Other	No	Other		Non-Lead - Copper	1980	3/4"	Other	Yes	Other	3/5/2024	Visual Inspection at the inlet side of the meter- Copper Line	Unknown	Single Family Residence	No	Unknown	No	
10761	356 N 8th	No	No	Unknown - Unlikely Lead	Don't know	1930	3/4"	Other	No	Other		Non-Lead - Copper	1930	3/4"	Other	Yes	Other	5/17/2024	Visual Inspection at the inlet side of the meter- Copper Line	Unknown	Single Family Residence	No	Unknown	No	
10770	454 N 8th	No	No	Unknown - Unlikely Lead	Don't know	1910	3/4"	Other	No	Other		Galvanized	1910	3/4"	Other	Yes	Other	12/19/2023	Visual Inspection at the inlet side of the meter- Galvanized Line	Unknown	Single Family Residence	No	Unknown	No	
10780	456 N 8th	No	No	Unknown - Unlikely Lead	Don't know	1915	3/4"	Other	No	Other		Non-Lead - Copper	1915	3/4"	Other	Yes	Other	8/30/2024	Visual Inspection at the inlet side of the meter- Copper Line	Unknown	Single Family Residence	No	Unknown	No	
10790	458 N 8th	No	No	Unknown - Unlikely Lead	Don't know	1917	3/4"	Other	No	Other		Non-Lead - Copper	1917	3/4"	Other	Yes	Other	3/21/2024	Visual Inspection at the inlet side of the meter- Copper Line	Unknown	Single Family Residence	No	Unknown	No	
10802	652 N 8th	No	No	Unknown - Unlikely Lead	Don't know	1910	3/4"	Other	No	Other		Non-Lead - Copper	1910	3/4"	Other	Yes	Other	12/19/2023	Visual Inspection at the inlet side of the meter- Copper Line	Unknown	Single Family Residence	No	Unknown	No	
10810	656 N 8th	No	No	Unknown - Unlikely Lead	Don't know	1978	3/4"	Other	No	Other		Non-Lead - Plastic	1978	3/4"	Other	Yes	Other	1/12/2024	Visual Inspection at the inlet side of the meter- Poly Line	Unknown	Single Family Residence	No	Unknown	No	
10821	658 N 8th	No	No	Unknown - Unlikely Lead	Don't know	1978	3/4"	Other	No	Other		Non-Lead - Copper	1978	3/4"	Other	Yes	Other	1/12/2024	Visual Inspection at the inlet side of the meter- Copper Line	Unknown	Single Family Residence	No	Unknown	No	
10825	655 N 8th	No	No	Unknown - Unlikely Lead	Don't know	1994	3/4'	Other	No	Other		Non-Lead - Copper	1994	3/4"	Other	Yes	Other	12/27/2023	Visual Inspection at the inlet side of the meter- Copper Line	Unknown	Single Family Residence	No	No	No	
10830	651 N 8th	No	No	Unknown - Unlikely Lead	Don't know	1958	3/4"	Other	No	Other		Non-Lead - Copper	1958	3/4"	Other	Yes	Other	12/27/2023	Visual Inspection at the inlet side of the meter- Copper Line	Unknown	Single Family Residence	No	Unknown	No	
10840	712 West G	No	No	Unknown - Unlikely Lead	Don't know	1912	3/4"	Other	No	Other		Non-Lead - Copper	1912	3/4"	Other	Yes	Other	12/29/2023	Visual Inspection at the inlet side of the meter- Copper Line	Unknown	Single Family Residence	No	Unknown	No	
10850	459 N 8th	No	No	Unknown - Unlikely Lead	Don't know	1933	3/4"	Other	No	Other		Non-Lead - Copper	1933	3/4"	Other	Yes	Other	1/17/2024	Visual Inspection at the inlet side of the meter- Copper Line	Unknown	Single Family Residence	No	Unknown	No	
10860	455 N 8th	No	No	Unknown - Unlikely Lead	Don't know	1930	3/4"	Other	No	Other		Non-Lead - Plastic	1930	3/4"	Other	Yes	Other	12/18/2023	Visual Inspection at the inlet side of the meter- Poly Line	Unknown	Single Family Residence	No	Unknown	No	
10880	452 N 8th	No	No	Unknown - Unlikely Lead	Don't know	1917	3/4"	Other	No	Other		Non-Lead - Plastic	1917	3/4"	Other	Yes	Other	12/28/2023	Visual Inspection at the inlet side of the meter- Poly Line	Unknown	Single Family Residence	No	Unknown	No	
10890	456 N 7th	No	No	Non-Lead - Plastic	Don't know	1994	3/4"	Service line repair or replacement record	No		Records from the Myrtle & N 7th Street Water Line Replacement 1994	Non-Lead - Copper	1909	3/4"	Other	Yes	Other	12/18/2023	Visual Inspection at the inlet side of the meter- Copper Line	Non-Lead	Single Family Residence	No	Unknown	No	
10900	460 N 7th	No	No	Non-Lead - Plastic	Don't know	1994	3/4"	Service line repair or replacement record	No		Records from the Myrtle & N 7th Street Water Line Replacement 1994	Non-Lead - Copper	1910	3/4"	Other	Yes	Other	9/10/2024	Visual Inspection at the inlet side of the meter- Copper Line	Non-Lead	Single Family Residence	No	Unknown	No	
10909	706 West G Street	No	No	Non-Lead - Plastic	Don't know	1994	3/4"	Service line repair or replacement record	No		Records from the Myrtle & N 7th Street Water Line Replacement 1994	Non-Lead - Plastic	1968	3/4"	Other	Yes	Other	12/19/2023	Visual Inspection at the inlet side of the meter- Poly Line	Non-Lead	Building	No	Unknown	No	
10910	706 West G Street	No	No	Unknown - Unlikely Lead	Don't know	1905	3/4"	Other	No	Other		Non-Lead - Plastic	1905	3/4"	Other	Yes	Other	12/19/2023	Visual Inspection at the inlet side of the meter- Poly Line	Unknown	Single Family Residence	No	Unknown	No	
10920	652 N 7th	No	No	Unknown - Unlikely Lead	Don't know	1956	3/4"	Other	No	Other		Non-Lead - Copper	1956	3/4"	Other	Yes	Other	1/9/2024	Visual Inspection at the inlet side of the meter- Copper Line	Unknown	Single Family Residence	No	Unknown	No	
10930	654 N 7th	No	No	Unknown - Unlikely Lead	Don't know	1913	3/4"	Other	No	Other		Non-Lead - Copper	1913	3/4"	Other	Yes	Other	9/6/2024	Visual Inspection at the inlet side of the meter- Copper Line	Unknown	Single Family Residence	No	Unknown	No	
10950	657 N 7th	No	No	Unknown - Unlikely Lead	Don't know	1955	3/4"	Other	No	Other		Non-Lead - Copper	1955	3/4"	Other	Yes	Other	2/10/2024	Visual Inspection at the inlet side of the meter- Copper Line	Unknown	Single Family Residence	No	Unknown	No	
10960	653 N 7th	No	No	Unknown - Unlikely Lead	Don't know	1910	3/4"	Other	No	Other		Non-Lead - Plastic	1910	3/4"	Other	Yes	Other	3/21/2024	Visual Inspection at the inlet side of the meter- Poly Line	Unknown	Single Family Residence	No	Unknown	No	
10970	651 N 7th	No	No	Unknown - Unlikely Lead	Don't know	1948	3/4"	Other	No	Other		Non-Lead - Copper	1948	3/4"	Other	Yes	Other	12/27/2023	Visual Inspection at the inlet side of the meter- Copper Line	Unknown	Single Family Residence	No	Unknown	No	
10980	616 West G	No	No	Non-Lead - Plastic	Don't know	1994	3/4"	Service line repair or replacement record	No		Records from the Myrtle & 7th Project 1994	Non-Lead - Plastic	1920	3/4"	Other	Yes	Other	1/22/2024	Visual Inspection at the inlet side of the meter- Poly Line	Non-Lead	Single Family Residence	No	Unknown	No	
10990	554 N 6th	No	No	Unknown - Unlikely Lead	Don't know	1903	3/4"	Other	No	Other		Non-Lead - Copper	1903	3/4"	Other	Yes	Other	1/11/2024	Visual Inspection at the inlet side of the meter- Copper Line	Unknown	Single Family Residence	No	Unknown	No	
11000	652 N 6th	No	No	Unknown - Unlikely Lead	Don't know	1910	3/4'	Other	No	Other		Non-Lead - Copper	1910	3/4"	Other	Yes	Other	1/8/2024	Visual Inspection at the inlet side of the meter- Copper Line	Unknown	Single Family Residence	No	Unknown	No	
11010	656 N 6th	No	No	Unknown - Unlikely Lead	Don't know	1956	3/4"	Other	No	Other		Non-Lead - Copper	1956	3/4"	Other	Yes	Other	1/18/2023	Visual Inspection at the inlet side of the meter- Copper Line	Unknown	Single Family Residence	No	Unknown	No	
11040	518 West G	No	No	Unknown - Unlikely Lead	Don't know	1910	3/4"	Other	No	Other		Non-Lead - Copper	1910	3/4"	Other	Yes	Other	3/14/2024	Visual Inspection at the inlet side of the meter- Copper Line	Unknown	Single Family Residence	No	Unknown	No	
11045	510 W G	No	No	Non-Lead - Plastic	No	2007	3/4"	Installation date after lead ban	Yes	Other		Non-Lead - Plastic	2007	3/4"	Installation date after lead ban	Yes	Other	2/6/2024	Visual Inspection at the inlet side of the meter- Poly Line	Non-Lead	Single Family Residence	No	No	No	
11052	510 Zane Avenue	No	No	Non-Lead - Plastic	No	2015	3/4"	Installation date after lead ban	Yes	Other		Non-Lead - Plastic	2015	3/4"	Installation date after lead ban	Yes	Other	1/9/2024	Visual Inspection at the inlet side of the meter- Poly Line	Non-Lead	Building	No	No	No	
11053	525 N 5th	No	No	Non-Lead - Plastic	No	2014	3/4"	Installation date after lead ban	Yes	Other		Non-Lead - Plastic	2014	3/4"	Installation date after lead ban	Yes	Other	1/23/2023	Visual Inspection at the inlet side of the meter- Poly Line	Non-Lead	Building	No	No	No	1
11070	406 West G	No	No	Unknown - Unlikely Lead	Don't know	1952	3/4"	Other	No	Other		Non-Lead - Copper	1952	3/4"	Other	Yes	Other	6/21/2024	Visual Inspection at the inlet side of the meter- Copper Line	Unknown	Single Family Residence	No	Unknown	No	
11075	300 North Street	No	No	Unknown - Unlikely Lead	Don't know	1980	3/4"	Other	No	Other		Non-Lead - Plastic	1980	3/4"	Other	Yes	Other	1/31/2024	Visual Inspection at the inlet side of the meter- Poly Line	Unknown	Single Family Residence	No	Unknown	No	
11077	310 N Street	No	No	Unknown - Unlikely Lead	No	1998	3/4"	Other	No	Other		Non-Lead - Plastic	1998	3/4"	Installation date after lead ban	Yes	Other	1/31/2024	Visual Inspection at the inlet side of the meter- Poly Line	Unknown	Single Family Residence	No	No	No	
11080	315 N Street	No	No	Unknown - Unlikely Lead	Don't know	1977	3/4"	Other	No	Other		Non-Lead - Plastic	1977	3/4"	Other	Yes	Other	1/31/2024	Visual Inspectioin at the inlet side of the meter- Poly Line	Unknown	Building	No	Unknown	No	
11100	651 N 6th	No	No	Non-Lead - Plastic	No	2021	3/4"	Installation date after lead ban	Yes	Other		Non-Lead - Plastic	2021	3/4"	Installation date after lead ban	Yes	Other	12/20/2023	Visual Inspection at the inlet side of the meter- Poly Line	Non-Lead	Single Family Residence	No	No	No	
11120	659 N 6TH	No	No	Non-Lead - Plastic	No	2023	3/4"	Installation date after lead ban	Yes	Other		Non-Lead - Plastic	2023	3/4"	Installation date after lead ban	Yes	Other	4/11/2023	Visual Inspection at the inlet side of the meter- Poly Line	Non-Lead	Single Family Residence	No	No	No	
11150	758 N 5th	No	No	Non-Lead - Plastic	No	2021	3/4"	Installation date after lead ban	Yes	Other		Non-Lead - Plastic	2021	3/4"	Installation date after lead ban	Yes	Other	2/1/2023	Visual Inspection at the inlet side of the meter- Poly Line	Non-Lead	Single Family Residence	No	No	No	
11170	855 N 6th	No	No	Non-Lead - Plastic	No	2021	3/4"	Installation date after lead ban	Yes	Other		Non-Lead - Plastic	2021	3/4"	Installation date after lead ban	Yes	Other		Customer Verification	Non-Lead	Single Family Residence	No	No	No	
20030	402 West C	No	No	Non-Lead - Copper	Don't know	1990	3/4"	Service line repair or replacement record	No	Other	Records/Map from 1990- State Highway Basin/Burlington Road Big Horn County	Non-Lead - Copper	1918	3/4"	Other	Yes	Other	12/20/2023	Visual Inspection at the inlet side of the meter- Copper Line	Non-Lead	Building	No	Unknown	No	
20035	415 Murphy	No	No	Non-Lead - Copper	No	2000	3"	Service line diameter is > 2 inches	Yes	Other		Non-Lead - Copper	2000	3"	Service line diameter is > 2 inches	Yes	Other	8/26/2024	Visual Inspection at the inlet side of the meter- Copper Line	Non-Lead	Building	No	No	No	
20050	420 West C	No	No	Non-Lead - Copper	Don't know	1990	1.5"	Service line repair or replacement record	No		Records/Map from 1990- State Highway Basin/Burlington Road Big Horn County	Non-Lead - Copper	1965	1.5"	Other	Yes	Other	8/26/2024	Visual Inspection at the inlet side of the meter- Copper Line	Non-Lead	Building	No	Unknown	No	
20060	425 Murphy	No	No	Unknown - Unlikely Lead	Don't know	1965	3/4"	Other	No	Other		Non-Lead - Other	1965	3/4"	Other	Yes	Other	1/22/2024	Cast Iron to Copper- Customer Identification with Material Line Survey	Unknown	Building	No	Unknown	No	
20065	427 Murphy	No	No	Unknown - Unlikely Lead	Don't know	1985	3/4"	Other	No	Other		Non-Lead - Copper	1985	3/4"	Other	Yes	Other	12/7/2023	Visual Inspection at the inlet side of the meter- Copper Line	Unknown	Building	No	Unknown	No	
20069	430 Murphy	No	No	Unknown - Unlikely Lead	No	2019	3/4"	Other	Yes	Other		Non-Lead - Plastic	2019	3/4"	Installation date after lead ban	Yes	Other	12/28/2023	Visual Inspection at the inlet side of the meter- Poly Line	Unknown	Building	No	No	No	
20070	412 Murphy	No	No	Unknown - Unlikely Lead	Don't know	1982	3/4"	Other	No	Other		Non-Lead - Copper	1982	3/4"	Other	Yes	Other	12/20/2023	Visual Inspection at the inlet side of the meter- Copper Line	Unknown	Building	No	Unknown	No	
20075	418 Murphy	No	No	Non-Lead - Copper	No	1991	3/4"	Installation date after lead ban	Yes	Other		Non-Lead - Copper	1991	3/4"	Installation date after lead ban	Yes	Other	1/22/2024	Visual Inspection at the inlet side of the meter- Copper Line	Non-Lead	Building	No	No	No	
20080	430 West C	No	No	Non-Lead - Copper	Don't know	1990	3/4"	Service line repair or replacement record	No		Records/Map from 1990- State Highway Basin/Burlington Road Big Horn County	Non-Lead - Copper	1953	3/4"	Other	Yes	Other	12/20/2023	Visual Inspection at the inlet side of the meter- Copper Line	Non-Lead	Building	No	Unknown	No	
20101	156 N 6th	No	No	Non-Lead - Plastic	No	2005	3/4"	Installation date after lead ban	Yes	Other		Non-Lead - Plastic	2005	3/4"	Installation date after lead ban	Yes	Other	1/6/2024	Visual Inspection at the inlet side of the meter- Poly Line	Non-Lead	Building	No	No	No	
20150	166 N 6th	No	No	Unknown - Unlikely Lead	Don't know	1902	3/4"	Other	No	Other		Non-Lead - Copper	1902	3/4"	Other	Yes	Other	4/2/2024	Visual Inspection at the inlet side of the meter- Copper Line	Unknown	Single Family Residence	No	Unknown	No	
20160	254 N 6th	No	No	Unknown - Unlikely Lead	Don't know	1982	3/4"	Other	No	Other		Non-Lead - Copper	1982	3/4"	Other	Yes	Other	1/18/2024	Visual Inspection at the inlet side of the meter- Copper Line	Unknown	Single Family Residence	No	Unknown	No	
20180	616 West D	No	No	Non-Lead - Copper	Don't know	1994	3/4"	Service line repair or replacement record	No		Records from the Myrtle & N 7th Street Water Line Replacement 1994	Non-Lead - Copper	1904	3/4"	Other	Yes	Other	2/9/2024	Visual Inspection at the inlet side of the meter- Copper Line	Non-Lead	Single Family Residence	No	Unknown	No	

20190	161 N 7th	No	No	Non-Lead - Plastic	Don't know	1994	3/4"	Service line repair or replacement record	No			Records from the Myrtle & N 7th Street Water Line Replacement 1994	Non-Lead - Copper	1975	3/4"	Other	Yes	Other	1/22/2024	Visual inspection at the inlet side of the meter- Copper Line	Non-Lead		Single Family Residence	No	Unknown	No
20260	121 N 7th	No	No	Unknown - Unlikely Lead	Don't know	1974	3/4"	Other	No	Other			Non-Lead - Copper	1974	3/4"	Other	Yes	Other	3/12/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Multiple Family Residence	No	Unknown	No
20272	710 West C	No	No	Non-Lead - Plastic	Don't know	1994	3/4"	Service line repair or replacement record	No			Records from the Myrtle & N 7th Street Water Line Replacement 1994	Non-Lead - Copper	1952	3/4"	Other	Yes	Other	3/15/2024	Visual inspection at the inlet side of the meter- Copper Line	Non-Lead		Multiple Family Residence	No	Unknown	No
20510	356 N 6th	No	No	Non-Lead - Copper		2024	3/4"	Service line repair or replacement record	No	Other		Mechanical Excavation on 10/9/2024. Repaired the curbstop. Copper Line from the water main	Non-Lead - Copper	1945		Other	Yes	Other	10/9/2024	Mechanical Excavation on 10/9/2024. Repaired the curbstop. Copper line on customer side of the curbstop.	Non-Lead		Single Family Residence	No	Unknown	No
20520	354 N 6th	No	No	Unknown - Unlikely Lead	Don't know	1950		Other	No	Other			Unknown - Unlikely Lead								Unknown					
20530	352 N 6th	No	No	Unknown - Unlikely Lead	Don't know	1927	3/4"	Other	No	Other			Non-Lead - Copper	1927	3/4"	Other	Yes	Other	1/16/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No
20540	272 N 6th	No	No	Unknown - Unlikely Lead	Don't know	1896		Other	No	Other			Unknown - Unlikely Lead								Unknown					
20560	516 West E	No	No	Unknown - Unlikely Lead	Don't know	1920	3/4"	Other	No	Other			Non-Lead - Copper	1920	3/4"	Other	Yes	Other	1/29/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No
20593	354 N 5th	No	No	Unknown - Unlikely Lead	Don't know	1990		Installation date after lead ban					Non-Lead - Plastic	1990	3/4"	Installation date after lead ban	Yes	Other	2/2/2024	Visual inspection at the inlet side of the meter- Poly Line	Unknown		Single Family Residence	No	Unknown	No
20594	512 West E Street	No	No	Unknown - Unlikely Lead	Don't know	2012	3/4"	Installation date after lead ban	No	Other			Non-Lead - Plastic	2012	3/4"	Other	Yes	Other	2/2/2024	Visual inspection at the inlet side of the meter- Poly	Unknown		Single Family Residence	No	No	No
20595	514 West E Street	No	No	Unknown - Unlikely Lead	Don't know	1990	3/4"	Other	No	Other			Non-Lead - Plastic	1990	3/4"	Other	Yes	Other	2/2/2024	Visual inspection at the inlet side of the meter- Poly	Unknown		Single Family Residence	No	No	No
20600	357 N 6th	No	No	Unknown - Unlikely Lead	Don't know	1935	3/4"	Other	No	Other			Non-Lead - Copper	1935	3/4"	Other	Yes	Other	7/25/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No
20605	515 West F	No	No	Unknown - Unlikely Lead	Don't know	1994	3/4"	Other	No	Other			Non-Lead - Copper	1994	3/4"	Installation date after lead ban	Yes	Other	1/18/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	No	No
20610	518 West F	No	No	Unknown - Unlikely Lead	Don't know	1925							Unknown - Unlikely Lead								Unknown					
20620	457 N 6th	No	No	Unknown - Unlikely Lead	Don't know	1919	3/4"	Other	No	Other			Non-Lead - Copper	1919	3/4"	Other	Yes	Other	1/17/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No
20630	459 N 6th	No	No	Unknown - Unlikely Lead	Don't know	1951	3/4"	Other	No	Other			Non-Lead - Plastic	1951	3/4"	Other	Yes	Other	1/17/2024	Visual inspection at the inlet side of the meter- Poly Line	Unknown		Single Family Residence	No	Unknown	No
20700	460 N 5th	No	No	Unknown - Unlikely Lead	Don't know	1930		Other	No	Other			Unknown - Unlikely Lead								Unknown					
20711	458 N 5th	No	No	Unknown - Unlikely Lead	Don't know	1910	3/4"	Other	No	Other			Non-Lead - Copper	1910	3/4"	Other	Yes	Other	2/6/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No
20720	456 N 5th	No	No	Unknown - Unlikely Lead	Don't know	1976	3/4"	Other	No	Other			Non-Lead - Copper	1976	3/4"	Other	Yes	Other	3/6/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No
20730	510 West F	No	No	Unknown - Unlikely Lead	Don't know	1950	3/4"	Other	No	Other			Non-Lead - Copper	1950	3/4"	Other	Yes	Other	1/16/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No
20750	415 West F	No	No	Unknown - Unlikely Lead	Don't know																Unknown					
20760	358 N 5th	No	No	Unknown - Unlikely Lead	Don't know	1909	3/4"	Other	No	Other			Non-Lead - Plastic		1909	Other	Yes	Other	3/12/2024	Visual inspection at the inlet side of the meter- Poly Line	Unknown					
20765	453 N 5th	No	No	Unknown - Unlikely Lead	Don't know	2018	3/4"	Other	No	Other			Non-Lead - Copper	2015	3/4"	Other	Yes	Other	1/16/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	No	No
20280	156 N 7th	No	No	Non-Lead - Plastic	Don't know	1994	3/4"	Service line repair or replacement record	No			Records from the Myrtle & N 7th Street Water Line Replacement 1994	Non-Lead - Copper	1920	3/4"	Other	Yes	Other	3/21/2024	Visual inspection at the inlet side of the meter- Copper Line	Non-Lead		Single Family Residence	No	Unknown	No
20290	160 N 7th	No	No	Non-Lead - Plastic	Don't know	1994	3/4"	Service line repair or replacement record	No			Records from the Myrtle & N 7th Street Water Line Replacement 1994	Non-Lead - Copper	1908	3/4"	Installation date after lead ban	No	Other			Non-Lead		Single Family Residence	No	Unknown	No
20300	162 N 7th	No	No	Non-Lead - Plastic	Don't know	1994	3/4"	Service line repair or replacement record	No			Records from the Myrtle & N 7th Street Water Line Replacement 1994	Non-Lead - Copper	1955	3/4"	Installation date after lead ban	No	Other			Non-Lead		Single Family Residence	No	Unknown	No
20310	254 N 7th	No	No	Non-Lead - Plastic	Don't know	1994	3/4"	Service line repair or replacement record	No			Records from the Myrtle & N 7th Street Water Line Replacement 1994	Non-Lead - Copper	1907	3/4"	Installation date after lead ban	Yes	Other	2/15/2024	Visual inspection at the inlet side of the meter- Copper Line	Non-Lead		Single Family Residence	No	Unknown	No
20320	714 West D	No	No	Unknown - Unlikely Lead	Don't know	1979	3/4"	Other	No	Other			Non-Lead - Copper	1979	3/4"	Other	Yes	Other	1/16/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No
20330	751 West D	No	No	Unknown - Unlikely Lead	Don't know	1909	3/4"	Other	No	Other			Non-Lead - Copper	1909	3/4"	Other	Yes	Other	2/22/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No
20340	255 N 8th	No	No	Unknown - Unlikely Lead	Don't know	1910	3/4"	Other	No	Other			Non-Lead - Copper	1910	3/4"	Other	Yes	Other	3/4/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No
20350	257 N 8th	No	No	Unknown - Unlikely Lead	Don't know	1952															Unknown					
20360	715 E Street	No	No	Unknown - Unlikely Lead	Don't know	1994	3/4"	Service line repair or replacement record	No			Records from the Myrtle & N 7th Street Water Line Replacement 1994	Non-Lead - Copper	2000	3/4"	Other	Yes	Other	2/6/2024	Visual inspection at the inlet side of the meter- Copper Line	Non-Lead		Single Family Residence	No	No	No
20370	617 West E	No	No	Non-Lead - Plastic	Don't know	1994	3/4"	Service line repair or replacement record	No			Records from the Myrtle & N 7th Street Water Line Replacement 1994	Non-Lead - Copper	1910	3/4"	Other	Yes	Other	4/5/2024	Visual inspection at the inlet side of the meter- Copper Line	Non-Lead		Single Family Residence	No	Unknown	No
20380	618 West E	No	No	Unknown - Unlikely Lead	Don't know	1900	3/4"	Other	No	Other			Non-Lead - Plastic	1900	3/4"	Other	Yes	Other	9/23/2024	Visual inspection at the inlet side of the meter- Poly Line	Unknown		Single Family Residence	No	Unknown	No
20400	355 N 7th	No	No	Non-Lead - Plastic	Don't know	1994	3/4"	Service line repair or replacement record	No			Records from the Myrtle & N 7th Street Water Line Replacement 1994	Non-Lead - Copper	1910	3/4"	Other	Yes	Other	3/5/2023	Visual inspection at the inlet side of the meter- Copper Line	Non-Lead		Single Family Residence	No	Unknown	No
20420	359 N 7th	No	No	Non-Lead - Plastic	Don't know	1994	3/4"	Service line repair or replacement record	No			Records from the Myrtle & N 7th Street Water Line Replacement 1994	Non-Lead - Copper	1900	3/4"	Other	Yes	Other	1/16/2024	Visual inspection at the inlet side of the meter- Copper Line	Non-Lead		Single Family Residence	No	Unknown	No
20450	451 N 7th	No	No	Non-Lead - Plastic	Don't know	1994	3/4"	Service line repair or replacement record	No			Records from the Myrtle & N 7th Street Water Line Replacement 1994	Non-Lead - Copper	1955	3/4"	Other	Yes	Other	3/6/2024	Visual inspection at the inlet side of the meter- Copper Line	Non-Lead		Single Family Residence	No	Unknown	No
20460	453 N 7th	No	No	Non-Lead - Plastic	Don't know	1995	3/4"	Service line repair or replacement record	No			Records from the Myrtle & N 7th Street Water Line Replacement 1994	Non-Lead - Copper	1955	3/4"	Other	Yes	Other	3/6/2024	Visual inspection at the inlet side of the meter- Copper Line	Non-Lead		Single Family Residence	No	Unknown	No
20470	455 N 7th	No	No	Non-Lead - Plastic	Don't know	1994	3/4"	Service line repair or replacement record	No			Records from the Myrtle & N 7th Street Water Line Replacement 1994	Non-Lead - Copper	1954	3/4"	Other	Yes	Other	3/29/2024	Visual inspection at the inlet side of the meter- Copper Line	Non-Lead		Single Family Residence	No	Unknown	No
20475	462 N 6th	No	No	Unknown - Unlikely Lead	Don't know	1920	3/4"	Other	No	Other			Non-Lead - Copper	1920	3/4"	Other	Yes	Other	1/28/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No
20490	458 N 6th	No	No	Unknown - Unlikely Lead	Don't know	1940	3/4"	Other	No	Other			Non-Lead - Copper	1940	3/4"	Other	Yes	Other	3/19/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No
20500	610 West F	No	No	Unknown - Unlikely Lead	Don't know	2001	3/4"	Other	No	Other			Non-Lead - Plastic	2001	3/4"	Installation date after lead ban	Yes	Other	2/2/2023	Visual inspection at the inlet side of the meter- Poly Line	Unknown		Single Family Residence	No	No	No
20505	358 N 6th	No	No	Unknown - Unlikely Lead	Don't know	1995	3/4"	Other	No	Other			Non-Lead - Copper	1995	3/4"	Installation date after lead ban	Yes	Other	3/14/2024	Visual Inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	No	No
20770	451 N 5th	No	No	Unknown - Unlikely Lead	Don't know	2002	3/4"	Other	No	Other			Non-Lead - Plastic	2002	3/4"	Installation date after lead ban	Yes	Other	3/20/2024	Visual Inspection at the inlet side of the meter- Poly Line	Unknown		Single Family Residence	No	No	No
20780	351 N 5th	No	No	Unknown - Unlikely Lead	Don't know	2008	3/4"	Other	No	Other			Non-Lead - Plastic	2008	3/4"	Installation date after lead ban	Yes	Other	2/6/2024	Visual Inspection at the inlet side of the meter- Poly Line	Unknown		Single Family Residence	No	No	No
220810	420 West E			Unknown - Unlikely Lead		1930	3/4"						Non-Lead - Copper	1930					4/2/2024	Visual Inspection at the inlet side of the meter	Unknown					
20940	356 N 4th	No	No	Unknown - Unlikely Lead	Don't know	1995	3/4"	Other	No	Other			Non-Lead - Plastic	1995	3/4"	Installation date after lead ban	Yes	Other	1/19/2024	Visual Inspection at the inlet side of the meter- Poly Line	Unknown		Single Family Residence	No	No	No
20950	360 N 4th	No	No	Unknown - Unlikely Lead	Don't know	1976	3/4"	Other	No	Other			Non-Lead - Copper	1976	3/4"	Other	Yes	Other	2/1/2024	Visual Inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No
20970	362 N 4th	No	No	Unknown - Unlikely Lead	Don't know	1940	3/4"	Other	No	Other			Non-Lead - Copper	1940	3/4"	Other	Yes	Other	3/26/2024	Visual Inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No
20890	456 N 4th	No	No	Unknown - Unlikely Lead		1940	3/4"						Unknown - Unlikely Lead								Unknown					
20900	460 N 4th	No	No	Unknown - Unlikely Lead		1901	3/4"						Non-Lead - Copper	1901	3/4"	Other	Yes	Other	1/31/2024	Visual Inspectionn at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No
20910	462 N 4th	No	No	Unknown - Unlikely Lead	Don't know	1937	3/4"	Other	No	Other			Non-Lead - Copper	1937	3/4"	Other	Yes	Other	9/13/2024	Visual Inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No
20920	405 West G	No	No	Unknown - Unlikely Lead	Don't know	2009	3/4"	Other	No	Other			Non-Lead - Copper	2009	3/4"	Installation date after lead ban	Yes	Other	1/31/2024	Visual Inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	No	No
20940	361 N 4th	No	No	Unknown - Unlikely Lead	Don't know	1905	3/4"	Other	No	Other			Non-Lead - Copper	1905	3/4"	Other	Yes	Other	4/2/2024	Visual Inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No
20960	314 West E	No	No	Unknown - Unlikely Lead	Don't know	1981	3/4"	Other	No	Other			Non-Lead - Copper	1981	3/4"	Other	Yes	Other	1/8/2024	Visual Inspection at the inlet side of the meter- Copper Line	Unknown		Building	No	Unknown	No
20961	355 N 4th	No	No	Unknown - Unlikely Lead	Don't know	2011	3/4"	Other	No	Other			Non-Lead - Plastic	2011	3/4"	Installation date after lead ban	Yes	Other	2/1/2024	Visual Inspection at the inlet side of the meter- Poly Line	Unknown		Building	No	No	No
20980	318 West D	No	No	Unknown - Unlikely Lead	Don't know	1984	3/4"	Other	No	Other			Non-Lead - Copper	1984	3/4"	Other	Yes	Other	1/4/2024	Visual Inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No
20990	314 West D	No	No	Unknown - Unlikely Lead	Don't know	1920	3/4"	Other	No	Other			Non-Lead - Copper	1920	3/4"	Other	Yes	Other	3/6/2024	Visual Inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No
21000	312 West D	No	No	Unknown - Unlikely Lead	Don't know	1976	3/4"	Other	No	Other			Non-Lead - Plastic	1976	3/4"	Other	Yes	Other	3/6/2024	Visual Inspection at the inlet side of the meter- Poly Line	Unknown		Single Family Residence	No	Unknown	No
21010	163 N 4th	No	No	Unknown - Unlikely Lead	Don't know	1900	3/4"	Other	No	Other			Non-Lead - Plastic	1900	3/4"	Other	Yes	Other	12/28/2023	Visual Inspection at the inlet side of the meter- Poly Line	Unknown		Single Family Residence	No	Unknown	No
21020	155 N 4th	No	No	Unknown - Unlikely Lead	Don't know	1987	3/4"	Other	No	Other			Non-Lead - Copper	1987	3/4"	Other	Yes	Other	1/10/2024	Visual Inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No
30010	218 West C	No	No	Unknown - Unlikely Lead	Don't know	1980	2"	Other	No	Other			Non-Lead - Copper	1980	2"	Other	Yes	Other	6/28/2024	Visual Inspection at the inlet side of the meter- Copper Line	Unknown		Building	No	Unknown	No
																				Visual Inspection at the					

30025	WYDOT-Engineers Shop	No	No	Unknown - Unlikely Lead	Don't know	1990	3"	Service line diameter is > 2 inches	No	Other		Non-Lead - Copper	1990	3"	Service line diameter is > 2 inches	Yes	Other	6/18/2024	Inlet side of the meter- Copper Line	Unknown		Building	No	No	No		
30030	WYDOT-Mechanic Shop	No	No	Unknown - Unlikely Lead	Don't know	2000	2"	Installation date after lead ban	No	Other		Non-Lead - Copper	2000	2"	Installation date after lead ban	Yes	Other	1/22/2024	Visual Inspection at the inlet side of the meter- Copper Line	Unknown		Building	No	No	No		
30080	356 East B	No	No	Unknown - Unlikely Lead	Don't know	1974	3/4"	Other	No	Other		Non-Lead - Copper	1974	3/4"	Other	Yes	Other	6/21/2024	Visual Inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No		
30090	351 East B	No	No	Unknown - Unlikely Lead	Don't know		3/4"	Other	No	Other		Non-Lead - Copper		3/4"	Other	Yes	Other	6/21/2024	Visual Inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No		
301000	352 East B			Unknown - Unlikely Lead								Non-Lead - Plastic	1915	3/4"	Other	Yes	Other	10/10/2024	Visual Inspection at the inlet side of the meter- Pex Line	Non-Lead		Single Family Residence	No	Unknown	No		
30120	316 S 2nd	No	No	Non-Lead - Plastic	Don't know	2014-Replaced	3/4"	Installation date after lead ban	No	Other		Non-Lead - Plastic	2014-Replaced	3/4"	Installation date after lead ban	Yes	Other	1/24/2023	New Water Line Project Mecklam Acres Project 2014	Non-Lead		Single Family Residence	No	Unknown	No		
30130	416 S 2nd	No	No	Non-Lead - Plastic	Don't know	2014-Replaced	3/4"	Installation date after lead ban	No	Other	Water Project 2014 Mecklam Acres	Non-Lead - Plastic	2014-Replaced	3/4"	Installation date after lead ban	Yes	Other	7/9/2024	New Water Line Project Mecklam Acres Project 2014	Non-Lead		Single Family Residence	No	Unknown	No		
30140	418 S 2nd	No	No	Non-Lead - Plastic	Don't know	2014-Replaced	3/4"	Installation date after lead ban	No	Other	Water Project 2014 Mecklam Acres	Non-Lead - Plastic	1978	3/4"	Installation date after lead ban					Non-Lead		Single Family Residence	No	Unknown	No		
30150	156 East Wyoming	No	No	Non-Lead - Plastic	Don't know	2014-Replaced	3/4"	Installation date after lead ban	No	Other	Water Project 2014 Mecklam Acres	Non-Lead - Plastic	2014-Replaced	3/4"	Installation date after lead ban	Yes	Other	2014	New Water Line Project Mecklam Acres Project 2014	Non-Lead		Single Family Residence	No	Unknown	No		
301600	153 East Wyoming	No	No	Non-Lead - Plastic	Don't know	2014-Replaced	3/4"	Installation date after lead ban	No	Other	Water Project 2014 Mecklam Acres	Non-Lead - Copper	1930	3/4"	Installation date after lead ban	Yes	Other	9/18/2024	Verified by the home owner	Non-Lead		Single Family Residence	No	Unknown	No		
30170	608 Cheyenne	No	No	Non-Lead - Plastic	Don't know	2014-Replaced	3/4"	Installation date after lead ban	No	Other	Water Project 2014 Mecklam Acres	Non-Lead - Plastic	1950	3/4"	Installation date after lead ban	No						Single Family Residence	No	Unknown	No		
30180	611 Cheyenne	No	No	Non-Lead - Plastic	Don't know	2014-Replaced	3/4"	Installation date after lead ban	No	Other	Water Project 2014 Mecklam Acres	Non-Lead - Plastic	1991	3/4"	Installation date after lead ban	Yes	Customer self-identification	9/18/2024		Non-Lead		Single Family Residence	No	Yes	No		
30190	353 East Wyoming	No	No	Non-Lead - Plastic	Don't know	1984	3/4"	Other	No	Other		Non-Lead - Plastic	1984	3/4"	Other	Yes	Other	6/21/2024	Verified on the outlet side of the meter to the house. Meter is in a pit making it easy to verify	Non-Lead		Single Family Residence	No	Unknown	Yes		
30210	205 Myrtle	No	No	Unknown - Unlikely Lead	Don't know	1950	3/4"	Other	No	Other		Non-Lead - Copper	1950	3/4"	Other	Yes	Other	8/13/2024	Visual Inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No		
30240	205 West Montana	No	No	Unknown - Unlikely Lead	Don't know	1949	3/4"	Other	No	Other		Non-Lead - Copper	1949	3/4"	Other	Yes	Other	6/20/2024	Visual Inspection at the inlet side of the meter- Copper Line	Unknown		Building	No	Unknown	No		
30245	200 Montana	No	No	Non-Lead - Plastic	Don't know	2017	3/4"	Installation date after lead ban	No		New service 2017	Non-Lead - Plastic	2017	3/4"	Other	Yes	Other	6/18/2024	Visual Inspection at the meter pit	Non-Lead		Building	No	Unknown	No		
30246	206 Montana	No	No	Unknown - Unlikely Lead	Don't know	1940	3/4"	Other	No	Other		Non-Lead - Copper	1940	3/4"	Other	Yes	Other	6/18/2024	Visual Inspection at the inlet side of the meter- Copper Line	Unknown		Building	No	Unknown	No		
30248	703 S 4th	No	No	Unknown - Unlikely Lead	Don't know	1948	3/4"	Other	No	Other	Homeowner states that the Town line is copper	Non-Lead - Plastic	2019	3/4"	Other	Yes	Customer self-identification	9/18/2024	Homeowner replaced the service line from curbstop to house in 2019 with poly line	Unknown		Single Family Residence	No	Unknown	No		
30250	320 Holdredge	No	No	Unknown - Unlikely Lead	Don't know	1955	3/4"	Other	No	Other		Non-Lead - Plastic	1955	3/4"	Other	Yes	Other	6/18/2024	Visual Inspection at the outlet side of the meter in the meter pit.	Unknown		Single Family Residence	No	Unknown	No		
30260	310 Holdredge	No	No	Unknown - Unlikely Lead	Don't know	1955	3/4"	Other	No	Other		Non-Lead - Plastic	1955	3/4"	Other	Yes	Other	6/18/2024	Visual Inspection at the outlet side of the meter in the meter pit. Poly Line	Unknown		Single Family Residence	No	Unknown	No		
30370	710 S 3rd	No	No	Unknown - Unlikely Lead	Don't know	1955	3/4"	Other	No	Other		Non-Lead - Plastic	1955	3/4"	Other	Yes	Other	6/18/2024	Visual Inspection at the outlet side of the meter in the meter pit.Poly Line	Unknown		Single Family Residence	No	Unknown	No		
30380	708 S 3rd	No	No	Unknown - Unlikely Lead	Don't know	1955	3/4"	Other	No	Other		Non-Lead - Plastic	1955	3/4"	Other	Yes	Other	6/20/2024	Visual Inspection at the outlet side of the meter in the meter pit.Poly Line	Unknown		Single Family Residence	No	Unknown	No		
30400	704 S 3rd	No	No	Unknown - Unlikely Lead	Don't know	1955	3/4"	Other	No	Other		Non-Lead - Copper	1955	3/4"	Other	Yes	Other	6/19/2024	Visual Inspection at the outlet side of the meter in the meter pit. Copper Line	Unknown		Single Family Residence	No	Unknown	No		
30410	702 S 3rd	No	No	Unknown - Unlikely Lead	Don't know	1955	3/4"	Other	No	Other		Non-Lead - Plastic	1955	3/4"	Other	Yes	Other	6/18/2024	Visual Inspection at the outlet side of the meter in the meter pit. Poly Line	Unknown		Single Family Residence	No	Unknown	No		
30415	305 Montana	No	No	Unknown - Unlikely Lead	Don't know	1955	3/4"	Other	No	Other		Non-Lead - Plastic	1955	3/4"	Other	Yes	Other	6/18/2024	Visual Inspection at the outlet side of the meter in the meter pit. Poly Line	Unknown		Single Family Residence	No	Unknown	No		
30418	707 S 4th	No	No	Unknown - Unlikely Lead	Don't know	1970	3/4"	Other	No	Other		Non-Lead - Plastic	1970	3/4"	Other	Yes	Other	6/18/2024	Visual Inspection at the outlet side of the meter in the meter pit. Poly Line	Unknown		Building	No	Unknown	No		
30430	608 S 3rd	No	No	Unknown - Unlikely Lead								Unknown - Unlikely Lead								Unknown							
30450	604 S 3rd	No	No	Unknown - Unlikely Lead	Don't know	1978	3/4"	Other	No	Other		Non-Lead - Copper	1978	3/4"	Other	Yes	Other	9/4/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No		
304600	301 Wyoming	No	No	Unknown - Unlikely Lead	Don't know	1978	3/4"	Other	No	Other		Non-Lead - Copper	1978	3/4"	Other	Yes	Other	7/26/2024	Visual Inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No		
30470	405 S 4th	No	No	Unknown - Unlikely Lead	Don't know	1948	3/4"	Other	No	Other		Non-Lead - Plastic	1948	3/4"	Other	Yes	Other	6/17/2024	Visual Inspection at the inlet side of the meter- Poly Line	Unknown		Building	No	Unknown	No		
304800	218 Wyoming	No	No	Unknown - Unlikely Lead	Don't know	1975	3/4"	Other	No	Other		Non-Lead - Copper	1975	3/4"	Other	Yes	Other	7/26/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No		
30520	405 S 3rd	No	No	Unknown - Unlikely Lead	Don't know	1930	3/4"	Other	No	Other		Non-Lead - Copper	1930	3/4"	Other	Yes	Other	6/28/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No		
30560	302 S 3rd	No	No	Unknown - Unlikely Lead	Don't know	1900	3/4"	Other	No	Other		Non-Lead - Copper	1900	3/4"	Other	Yes	Other	9/12/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No		
30580	215 S 3rd	No	No	Unknown - Unlikely Lead	Don't know	1920	3/4"	Other	No	Other		Non-Lead - Copper	1920	3/4"	Other	Yes	Other	2/15/2023	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No		
30590	211 S 3rd	No	No	Unknown - Unlikely Lead	Don't know	1985	3/4"	Other	No	Other		Non-Lead - Copper	1985	3/4"	Other	Yes	Other	8/12/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No		
30610	209 S 3rd	No	No	Unknown - Unlikely Lead	Don't know	1976	3/4"	Other	No	Other		Non-Lead - Plastic	1976	3/4"	Other	Yes	Other	6/24/2024	Visual inspection at the inlet side of the meter- Poly Line	Unknown		Single Family Residence	No	Unknown	No		
30620	205 S 3rd	No	No	Unknown - Unlikely Lead	Don't know	1978	3/4"	Other	No	Other		Non-Lead - Plastic	1978	3/4"	Other	Yes	Other	8/12/2024	Visual inspection at the inlet side of the meter- Poly Line	Unknown		Single Family Residence	No	Unknown	No		
30640	118 S 3rd	No	No	Non-Lead - Plastic	Don't know	2002	3/4"	Installation date after lead ban	No	Other		Non-Lead - Plastic	2002	3/4"	Installation date after lead ban	Yes	Other	6/20/2024	Visual inspection at the inlet side of the meter- Poly Line	Non-Lead		Single Family Residence	No	Unknown	No		
30670	309 West C	No	No	Unknown - Unlikely Lead	Don't know	1920	3/4"	Other	No	Other		Non-Lead - Copper	1920	3/4"	Other	Yes	Other	8/23/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No		
30675	311 West C	No	No	Unknown - Unlikely Lead	Don't know	1930	3/4"	Other	No	Other		Non-Lead - Copper	1930	3/4"	Other	Yes	Other	1/24/2023	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Building	No	Unknown	No		
30690	105 S 4th	No	No	Unknown - Unlikely Lead	Don't know	1935	3/4"	Other	No	Other		Non-Lead - Copper	1935	3/4"	Other	Yes	Other	12/12/2023	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Building	No	Unknown	No		
30720	111 S 4th	No	No	Unknown - Unlikely Lead	Don't know	1940	3/4"	Other	No	Other		Non-Lead - Copper	1940	3/4"	Other	Yes	Other	12/12/2023	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Building	No	Unknown	No		
30740	115 S 4th	No	No	Unknown - Unlikely Lead	Don't know	1930	3/4"	Other	No	Other		Non-Lead - Copper	1930	3/4"	Other	Yes	Other	12/15/2023	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Building	No	Unknown	No		
30750	121 S 4th	No	No	Unknown - Unlikely Lead	Don't know	1917	3/4"	Other	No	Other		Non-Lead - Copper	1917	3/4"	Other	Yes	Other	12/6/2023	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Building	No	Unknown	No		
30770	123 S 4th	No	No	Unknown - Unlikely Lead	Don't know	1920	3/4"	Other	No	Other		Non-Lead - Copper	1920	3/4"	Other	Yes	Other	6/20/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Building	No	Unknown	No		
30787	209 S 4th	No	No	Unknown - Unlikely Lead	Don't know	1920	3/4"	Other	No	Other		Non-Lead - Copper	1920	3/4"	Other	Yes	Other	1/23/2023	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Building	No	Unknown	No		
30850	213 & 215 S 4th	No	No	Unknown - Unlikely Lead	Don't know	1977	3/4"	Other	No	Other		Non-Lead - Copper	1977	3/4"	Other	Yes	Other	7/18/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Building	No	Unknown	No		
30880	305 S 4th	No	No	Unknown - Unlikely Lead	Don't know	1979	3/4"	Other	No	Other		Non-Lead - Copper	1979	3/4"	Other	Yes	Other	6/14/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Building	No	Unknown	No		
30900	405 S 4th	No	No	Unknown - Unlikely Lead	Don't know	1948	3/4"	Other	No	Other		Non-Lead - Plastic	1948	3/4"	Other	Yes	Other	6/17/2024	Visual inspection at the inlet side of the meter- Poly Line	Unknown		Building	No	Unknown	No		
30910	416 S 3rd	No	No	Unknown - Unlikely Lead	Don't know	1969	3/4"	Other	No	Other		Non-Lead - Copper	1969	3/4"	Other	Yes	Other	7/18/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Building	No	Unknown	No		
30920	406 S 3rd	No	No	Non-Lead - Plastic	Don't know	1999	3/4"	Installation date after lead ban	Yes	Other		Non-Lead - Plastic	1999	3/4"	Installation date after lead ban	Yes	Other	6/17/2024	Visual inspection at the inlet side of the meter- Poly Line	Non-Lead		Building	No	No	No		
30950	310 Wyoming	No	No	Unknown - Unlikely Lead	Don't know		3/4"	Other	No	Other		Non-Lead - Copper		3/4"	Other	Yes	Other	6/17/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Building	No	Unknown	No		
30970	609 S 4th	No	No	Unknown - Unlikely Lead	Don't know	1958	3/4"	Other	No	Other		Non-Lead - Plastic	1958	3/4"	Other	Yes	Other	6/24/2024	Visual inspection at the inlet side of the meter- Pex Line	Unknown		Building	No	Unknown	No		
30980	611 S 4th	No	No	Unknown - Unlikely Lead	Don't know	1916	3/4"	Other	No	Other		Non-Lead - Copper	1916	3/4"	Other	Yes	Other	7/25/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No		
30990	615 S 4th	No	No	Unknown - Unlikely Lead	Don't know	Vacant Lot	3/4"	Other	No	Other		Non-Lead - Copper	Vacant lot	3/4"	Other	Yes	Other	7/30/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Other	No	Unknown	No		
31000	617 S 4th	No	No	Unknown - Unlikely Lead	Don't know	Vacant Lot	3/4"	Other	No	Other		Non-Lead - Copper	Vacant lot	3/4"	Other	Yes	Other	7/30/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Other	No	Unknown	No		
31010	315 Holdredge	No	No	Unknown - Unlikely Lead	Don't know	1970	3/4"	Other	No	Other		Non-Lead - Plastic	1970	3/4"	Other	Yes	Other	4/12/2024	Visual inspection at the meter pit-PVC Line	Unknown		Other	No	Unknown	No		
31030	BHC Fair	No	No	Non-Lead - Copper	Don't know	1998	3/4"	Other	No	Other		Non-Lead - Copper	1998	3/4"	Installation date after lead ban	Yes	Other	6/27/2024	Visual inspection at the inlet side of the meter- Copper Line	Non-Lead		Other	No	Unknown	No		
31040	110 East Big Horn Ave	No	No	Non-Lead - Plastic	Don't know	1998	3/4"	Other	No	Other		Non-Lead - Plastic	1998	3/4"	Other	Yes	Other		Customer identification Per Water Line Material Survey	Non-Lead		Single Family Residence	No	Unknown	No		
31045	1005 Cloud Peak Ave	No	No	Non-Lead - Plastic	Don't know	1998	3/4"	Other	No	Other		Non-Lead - Plastic	1998	3/4"	Installation date after lead ban				Line was installed by SBHC Water District	Non-Lead		Single Family Residence	No	Unknown	No		
31100	854 Highway 20 S	No	No	Non-Lead - Plastic	Don't know	1998	3/4"	Installation date after lead ban	No	Other		Non-Lead - Plastic	1998	3/4"	Installation date after lead ban				Line was installed by SBHC Water District	Non-Lead		Single Family Residence	No	Unknown	No		
31110	510 West Center	No	No	Non-Lead - Plastic	Don't know	1998	3/4"	Installation date after lead ban	No	Other		Non-Lead - Plastic	1998	3/4"	Installation date after lead ban				Line was installed by SBHC Water District	Non-Lead		Single Family Residence	No	Unknown	No		
31175	902 S 4th	No	No	Unknown - Unlikely Lead	Don't know	1953	3/4"	Other	No	Other		Non-Lead - Copper	1953	3/4"	Other	Yes	Other	8/1/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Building	No	Unknown	No		

31180	802 S 4th	No	No	Unknown - Unlikely Lead	Don't know	1917	3/4"	Other	No	Other		Non-Lead - Copper	1917	3/4"	Other	Yes	Other	1/9/2024	Visual Inspection at the inet side of the meter- Copper Line	Unknown	Single Family Residence	No	Unknown	No
31200	415 Holdredge	No	No	Unknown - Unlikely Lead	Don't know	1958	3/4"	Other	No	Other		Non-Lead - Copper	1929	3/4"	Other	Yes	Other	8/20/2024	Visual Inspection at the inlet side of the meter- Copper Line	Unknown	Single Family Residence	No	Unknown	No
40040	403 West C	No	No	Non-Lead - Copper	Don't know	1990	3/4"	Service line repair or replacement record	No		Records/Map from 1990- State Highway Basin/Burlington Road Big Horn County	Non-Lead - Copper	1930	3/4"	Other	Yes	Other	2/14/2024	Visual Inspection at the inlet side of the meter- Copper Line	Non-Lead	Building	No	Unknown	No
40043	405 West C	No	No	Non-Lead - Copper	Don't know	1990	3/4"	Service line repair or replacement record	No		Records/Map from 1990- State Highway Basin/Burlington Road Big Horn County	Non-Lead - Copper	1920	3/4"	Other	Yes	Other	2/1/2024	Visual Inspection at the inlet side of the meter- Copper Line	Non-Lead	Building	No	Unknown	No
40045	407 West C	No	No	Non-Lead - Copper	Don't know	1990	3/4"	Service line repair or replacement record	No		Records/Map from 1990- State Highway Basin/Burlington Road Big Horn County	Non-Lead - Copper		3/4"	Other	Yes	Other	12/28/2024	Visual Inspection at the inlet side of the meter- Copper Line	Non-Lead	Building	No	Unknown	No
40050	409 West C	No	No	Non-Lead - Copper	Don't know	1990	3/4"	Service line repair or replacement record	No		Records/Map from 1990- State Highway Basin/Burlington Road Big Horn County	Non-Lead - Copper	1917	3/4"	Other	Yes	Other	12/28/2024	Visual Inspection at the inlet side of the meter- Copper Line	Non-Lead	Building	No	Unknown	No
40060	411 West C	No	No	Non-Lead - Copper	Don't know	1990	3/4"	Service line repair or replacement record	No		Records/Map from 1990- State Highway Basin/Burlington Road Big Horn County	Non-Lead - Copper	1998	3/4"	Other	Yes	Other	1/24/2024	Visual Inspection at the inlet side of the meter- Copper Line	Non-Lead	Building	No	No	No
40070	417 West C	No	No	Non-Lead - Copper	Don't know	1990	3/4"	Service line repair or replacement record	No		Records/Map from 1990- State Highway Basin/Burlington Road Big Horn County	Non-Lead - Copper	1935	3/4"	Other	Yes	Other	9/27/2024	Visual Inspection at the inlet side of the meter- Copper Line	Non-Lead	Building	No	Unknown	No
40080	419 West C	No	No	Non-Lead - Copper	Don't know	1990	3/4"	Service line repair or replacement record	No		Records/Map from 1990- State Highway Basin/Burlington Road Big Horn County	Non-Lead - Copper	1990	3/4"	Installation date after lead ban					Non-Lead				
40100	114 S 4th	No	No	Unknown - Unlikely Lead	Don't know	1931	3/4"	Other	No	Other		Non-Lead - Copper	1931	3/4"	Other	Yes	Other	12/13/2024	Visual Inspection at the inlet side of the meter- Copper Line	Unknown	Building	No	Unknown	No
40170	206 S 4th	No	No	Unknown - Unlikely Lead	Don't know	1950	3/4"	Other	No	Other		Non-Lead - Copper	1950	3/4"	Other	Yes	Other	6/25/2024	Visual Inspection at the inlet side of the meter- Copper Line	Unknown	Building	No	Unknown	No
40180	210 S 4th	No	No	Unknown - Unlikely Lead																Unknown				
40190	220 S 4th	No	No	Unknown - Unlikely Lead	Don't know	1933	3/4"	Other	No	Other		Non-Lead - Copper	1933	3/4	Other	Yes	Other	8/23/2024	Visual Inspection at the inlet side of the meter- Copper Line	Unknown	Building	No	Unknown	No
4210	420 S 4th	No	No	Unknown - Unlikely Lead	Don't know	1955	3/4"	Other	No	Other		Non-Lead - Copper	1955	3/4"	Other	Yes	Other	6/21/2024	Visual Inspection at the inlet side of the meter- Copper Line	Unknown	Building	No	Unknown	No
40200	415 S Avenue	No	No	Unknown - Unlikely Lead	Don't know	2017	2"	Installation date after lead ban	No	Other		Non-Lead - Plastic	2017	2"	Other	Yes	Other	2017		Unknown	Building	No	Unknown	No
40220	406 S 4th	No	No	Unknown - Unlikely Lead	Don't know	1978	3/4"	Other	No	Other		Non-Lead - Plastic	1978	3/4"	Other	Yes	Other	12/28/2023	Visual Inspection at the inlet side of the meter- Poly Line	Unknown	Building	No	Unknown	No
40240	502 S 4th	No	No	Unknown - Unlikely Lead	Don't know	1910	3/4"	Other	No	Other		Non-Lead - Copper	1910	3/4"	Other	Yes	Other	7/31/2024	Visual Inspection at the inlet side of the meter- Copper Line	Unknown	Single Family Residence	No	Unknown	No
40260	508 S 4th	No	No	Unknown - Unlikely Lead	Don't know	1917	3/4"	Other	No	Other		Non-Lead - Copper	1917	3/4"	Other	Yes	Other	7/26/2024	Visual Inspection at the inlet side of the meter- Copper Line	Unknown	Single Family Residence	No	Unknown	No
40300	518 S 4th	No	No	Unknown - Unlikely Lead	Don't know	1940	3/4"	Other	No	Other		Non-Lead - Copper	1940	3/4"	Other	Yes	Other	8/14/2024	Visual Inspection at the inlet side of the meter- Copper Line	Unknown	Single Family Residence	No	Unknown	No
40310	520 S 4th	No	No	Unknown - Unlikely Lead	Don't know	1940	3/4"	Other	No	Other		Non-Lead - Copper	1940	3/4"	Other	Yes	Other	9/10/2024	Visual Inspection at the inlet side of the meter- Copper Line	Unknown	Single Family Residence	No	Unknown	No
40320	606 S 4th	No	No	Unknown - Unlikely Lead	Don't know	1973	3/4"	Other	No	Other		Non-Lead - Copper	1973	3/4"	Other	Yes	Other	7/25/2024	Visual Inspection at the inlet side of the meter- Copper Line	Unknown	Building	No	Unknown	No
40341	612 S 4th	No	No	Unknown - Unlikely Lead	Don't know	1952	3/4"	Other	No	Other		Non-Lead - Copper	1952	3/4"	Other	Yes	Other	7/16/2024	Visual Inspection at the inlet side of the meter- Copper Line	Unknown	Single Family Residence	No	Unknown	No
40350	616 S 4th	No	No	Unknown - Unlikely Lead	Don't know	1918	3/4"	Other	No	Other		Non-Lead - Copper	1918	3/4"	Other	Yes	Other	6/21/2024	Visual Inspection at the inlet side of the meter- Copper Line	Unknown	Single Family Residence	No	Unknown	No
40360	702 S 4th	No	No	Unknown - Unlikely Lead	Don't know	1935	3/4"	Other	No	Other		Non-Lead - Copper	1935	3/4"	Other	Yes	Other	9/4/2024	Visual Inspection at the inlet side of the meter- Copper Line	Unknown	Single Family Residence	No	Unknown	No
40370	706 S 4th	No	No	Unknown - Unlikely Lead	Don't know	1910	3/4"	Other	No	Other		Non-Lead - Copper	1910	3/4"	Other	Yes	Other	6/17/2024	Visual Inspection at the inlet side of the meter- Copper Line	Unknown	Single Family Residence	No	Unknown	No
40380	708 S 4th	No	No	Unknown - Unlikely Lead	Don't know	1910	3/4"	Other	No	Other		Non-Lead - Copper	1910	3/4"	Other	Yes	Other	6/27/2024	Visual Inspection at the inlet side of the meter- Copper Line	Unknown	Single Family Residence	No	Unknown	No
40390	712 S 4th	No	No	Unknown - Unlikely Lead	Don't know	1910	3/4"	Other	No	Other		Non-Lead - Copper	1910	3/4"	Other	Yes	Other	10/3/2024	Visual Inspections at the inlet side of the meter- Copper Line	Unknown				
40400	711 S 5th	No	No	Unknown - Unlikely Lead	Don't know	1924	3/4"	Other	No	Other		Non-Lead - Copper	1924	3/4"	Other	Yes	Other	8/30/2024	Visual Inspection at the inlet side of the meter- Copper Line	Unknown	Single Family Residence	No	Unknown	No
40410	707 S 5th	No	No	Unknown - Unlikely Lead	Don't know	1953	3/4"	Other	No	Other		Non-Lead - Copper	1953	3/4"	Other	Yes	Other	6/26/2024	Visual Inspection at the inlet side of the meter- Copper Line	Unknown	Single Family Residence	No	Unknown	No
40430	701 S 5th	No	No	Unknown - Unlikely Lead	Don't know	1914	3/4"	Other	No	Other		Non-Lead - Copper	1914	3/4"	Other	Yes	Other	6/24/2024	Visual Inspection at the inlet side of the meter- Copper Line	Unknown	Single Family Residence	No	Unknown	No
40450	607 S 5th	No	No	Unknown - Unlikely Lead	Don't know	1947	3/4"	Other	No	Other		Non-Lead - Copper	1947	3/4"	Other	Yes	Other	7/23/2024	Visual Inspection at the inlet side of the meter- Copper Line	Unknown	Single Family Residence	No	Unknown	No
40461	419 Wyoming Ave	No	No	Unknown - Unlikely Lead	Don't know	1920	3/4"	Other	No	Other		Non-Lead - Copper	1920	3/4"	Other	Yes	Other	1/22/2024	Visual Inspection at the inlet side of the meter- Copper Line	Unknown	Single Family Residence	No	Unknown	No
40470	414 Wyoming Ave	No	No	Unknown - Unlikely Lead	Don't know	1942	3/4"	Other	No	Other		Non-Lead - Copper	1942	3/4"	Other	Yes	Other	9/9/2024	Visual Inspection at the inlet side of the meter- Copper Line	Unknown	Single Family Residence	No	Unknown	No
40480	418 Wyoming Ave	No	No	Unknown - Unlikely Lead	Don't know	1910	3/4"	Other	No	Other		Non-Lead - Copper	1910	3/4"	Other	Yes	Other	8/1/2024	Visual Inspection at the inlet side of the meter- Copper Line	Unknown	Single Family Residence	No	Unknown	No
40490	511 S 5th	No	No	Unknown - Unlikely Lead	Don't know	1908	3/4"	Other	No	Other		Non-Lead - Copper	1908	3/4"	Other	Yes	Other	6/20/2024	Visual Inspection at the inlet side of the meter- Copper Line	Unknown	Single Family Residence	No	Unknown	No
40492	511 S 5th	No	No	Unknown - Unlikely Lead	Don't know	Motor Home	3/4"	Other	No	Other		Non-Lead - Plastic	Motor Home	3/4"	Other	Yes	Other	8/28/2024	Visual Inspection at the inlet side of the meter- Poly Line	Unknown	Single Family Residence	No	Unknown	No
40495	507 S 5th	No	No	Unknown - Unlikely Lead	Don't know	1917	3/4"	Other	No	Other		Non-Lead - Plastic	1917	3/4"	Other	Yes	Other	8/29/2024	Visual Inspection at the inlet side of the meter- Poly Line	Unknown	Single Family Residence	No	Unknown	No
40500	413 Myrtle	No	No	Non-Lead - Plastic	Don't know	1994	3/4"	Service line repair or replacement record	No		Records from the Myrtle & N 7th Street Water Line Replacement 1994	Non-Lead - Plastic	1910	3/4"	Other	Yes	Other	6/24/2024	Visual Inspection at the inlet side of the meter- Poly Line	Non-Lead	Single Family Residence	No	Unknown	No
40570	207 S 5th	No	No	Non-Lead - Copper	Don't know	1980	3/4"	Other	No	Other		Non-Lead - Copper	1980	3/4"	Other	Yes	Other	6/18/2024	Visual Inspection at the inlet side of the meter- Copper Line	Non-Lead	Single Family Residence	No	Unknown	No
40600	412 West B	No	No	Unknown - Unlikely Lead	Don't know	1952	3/4"	Other	No	Other		Non-Lead - Copper	1952	3/4"	Other	Yes	Other	9/18/2024	Visual Inspection at the inlet side of the meter- Copper Line	Unknown	Building	No	Unknown	No
40610	109 S 5th	No	No	Unknown - Unlikely Lead	Don't know	1945	3/4"	Other	No	Other		Non-Lead - Copper	1940	3/4"	Other	Yes	Other	1/31/2024	Visual Inspection at the inlet side of the meter- Copper Line	Unknown	Single Family Residence	No	Unknown	No
40620	416 West B	No	No	Unknown - Unlikely Lead	Don't know	1945	3/4"	Other	No	Other		Non-Lead - Copper	1945	3/4"	Other	Yes	Other	7/29/2024	Visual Inspection at the inlet side of the meter- Copper Line	Unknown	Single Family Residence	No	Unknown	No
40630	108 S 5th			Unknown - Unlikely Lead																Unknown				
40650	116 S 5th	No	No	Non-Lead - Copper	Don't know	1993	3/4"	Installation date after lead ban	No	Other		Non-Lead - Copper	1993	3/4"	Other	Yes	Other	12/28/2023	Visual Inspection at the inlet side of the meter- Copper Line	Non-Lead	Single Family Residence	No	Unknown	No
40670	511 West B	No	No	Unknown - Unlikely Lead	Don't know	1967	3/4"	Other	No	Other		Non-Lead - Copper	1967	3/4"	Other	Yes	Other	8/21/2024	Visual Inspection at the inlet side of the meter- Copper Line	Unknown	Building	No	Unknown	No
40680	509 West B	No	No	Unknown - Unlikely Lead	Don't know	1967	3/4"	Other	No	Other		Non-Lead - Copper	1967	3/4"	Other	Yes	Other	8/21/2024	Visual Inspection at the inlet side of the meter- Copper Line	Unknown	Building	No	Unknown	No
40690	202 S 5th	No	No	Unknown - Unlikely Lead	Don't know	1908	3/4"	Other	No	Other		Non-Lead - Copper	1908	3/4"	Other	Yes	Other	7/5/2024	Visual Inspection at the inlet side of the meter- Copper Line	Unknown	Single Family Residence	No	Unknown	No
40710	210 S 5th	No	No	Unknown - Unlikely Lead	Don't know	1956	3/4"	Other	No	Other		Non-Lead - Copper	1956	3/4"	Other	Yes	Other	8/12/2024	Visual Inspection at the inlet side of the meter- Copper Line	Unknown	Building	No	Unknown	No
40720	503 West A	No	No	Unknown - Unlikely Lead	Don't know	1973	3/4"	Other	No	Other		Non-Lead - Copper	1973	3/4"	Other	Yes	Other	6/28/2024	Visual Inspection at the inlet side of the meter- Copper Line	Unknown	Single Family Residence	No	Unknown	No
40730	306 S 5th	No	No	Unknown - Unlikely Lead	Don't know	1974	3/4"	Other	No	Other		Non-Lead - Copper	1974	3/4"	Other	Yes	Other	6/18/2024	Visual Inspection at the inlet side of the meter- Copper Line	Unknown	Single Family Residence	No	Unknown	No
40740	404 S 5th	No	No	Unknown - Unlikely Lead	Don't know	1994	3/4"	Other	No	Other		Non-Lead - Copper	1994	3/4"	Other	Yes	Other	6/28/2024	Visual Inspection at the inlet side of the meter- Copper Line	Unknown	Single Family Residence	No	Unknown	No
40760	408 S 5th	No	No	Unknown - Unlikely Lead	Don't know	1973	3/4"	Other	No	Other		Non-Lead - Copper	1973	3/4"	Other	Yes	Other	8/9/2024	Visual Inspection at the inlet side of the meter- Copper Line	Unknown	Single Family Residence	No	Unknown	No
40770	412 S 5th	No	No	Unknown - Unlikely Lead	Don't know	1975	3/4"	Other	No	Other		Non-Lead - Copper	1975	3/4"	Other	Yes	Other	6/24/2024	Visual Inspection at the inlet side of the meter- Copper Line	Unknown	Single Family Residence	No	Unknown	No
40780	416 S 5th	No	No	Unknown - Unlikely Lead	Don't know	1910	3/4"	Other	No	Other		Non-Lead - Copper	1910	3/4"	Other	Yes	Other	6/14/2024	Visual Inspection at the inlet side of the meter- Copper Line	Unknown	Single Family Residence	No	Unknown	No
40790	503 Myrtle			Unknown - Unlikely Lead																Unknown				
40810	506 S 5th			Unknown - Unlikely Lead																Unknown				
40820	508 S 5th	No	No	Unknown - Unlikely Lead	Don't know	1908	3/4"	Other	No	Other		Non-Lead - Copper	1908	3/4"	Other	Yes	Other	4/12/2023	Visual Inspection at the inlet side of the meter- Copper Line	Unknown	Single Family Residence	No	Unknown	No
40830	510 S 5th	No	No	Unknown - Unlikely Lead	Don't know	1976	3/4"	Other	No	Other		Non-Lead - Copper	1976	3/4"	Other	Yes	Other	6/18/2024	Visual Inspection at the inlet side of the meter- Copper Line	Unknown	Single Family Residence	No	Unknown	No
40840	514 S 5th	No	No	Unknown - Unlikely Lead	Don't know	1910	3/4"	Other	No	Other		Non-Lead - Copper	1910	3/4"	Other	Yes	Other	6/14/2024	Visual Inspection at the inlet side of the meter- Copper Line	Unknown	Single Family Residence	No	Unknown	No
40850	602 S 5th	No	No	Unknown - Unlikely Lead	Don't know	1905	3/4"	Other	No	Other		Non-Lead - Copper	1905	3/4"	Other	Yes	Other	4/19/2024	Visual Inspection at the inlet side of the meter- Copper Line	Unknown	Single Family Residence	No	Unknown	No
40870	608 S 5th	No	No	Unknown - Unlikely Lead	Don't know	1949	3/4"	Other	No	Other		Non-Lead - Copper	1949	3/4"	Other	Yes	Other	8/1/2024	Visual Inspection at the inlet side of the meter- Copper Line	Unknown	Single Family Residence	No	Unknown	No
40890	612 S 5th	No	No	Unknown - Unlikely Lead	Don't know	1912	3/4"	Other	No	Other		Non-Lead - Copper	1912	3/4"	Other	Yes	Other	8/22/2024	Visual Inspection at the inlet side of the meter- Copper Line	Unknown	Single Family Residence	No	Unknown	No

40900	505 Montana	No	No	Unknown - Unlikely Lead	Don't know	1955	3/4"	Other	No	Other		Non-Lead - Copper	1955	3/4"	Other	Yes	Other	6/20/2024	inlet side of the meter-Copper Line	Unknown		Single Family Residence	No	Unknown	No
40910	704 S 5th	No	No	Unknown - Unlikely Lead	Don't know	1945	3/4"	Other	No	Other		Non-Lead - Copper	1945	3/4"	Other	Yes	Other	9/4/2024	Visual Inspection at the inlet side of the meter-Copper Line	Unknown		Single Family Residence	No	Unknown	No
40920	706 S 5th	No	No	Unknown - Unlikely Lead	Don't know	1945	3/4"	Other	No	Other		Non-Lead - Copper	1945	3/4"	Other	Yes	Other	6/18/2024	Visual Inspection at the inlet side of the meter-Copper Line	Unknown		Single Family Residence	No	Unknown	No
40930	708 S 5th	No	No	Unknown - Unlikely Lead	Don't know	1945	3/4"	Other	No	Other		Non-Lead - Copper	1945	3/4"	Other	Yes	Other	6/17/2024	Visual Inspection at the inlet side of the meter-Copper Line	Unknown		Single Family Residence	No	Unknown	No
40940	710 S 5th	No	No	Unknown - Unlikely Lead	Don't know	1945	3/4"	Other	No	Other		Non-Lead - Copper	1945	3/4"	Other	Yes	Other	8/7/2024	Visual Inspection at the inlet side of the meter-Copper Line	Unknown		Single Family Residence	No	Unknown	No
40950	508 Holdredge	No	No	Unknown - Unlikely Lead	Don't know	1949	3/4"	Other	No	Other		Non-Lead - Copper	1949	3/4"	Other	Yes	Other	6/17/2024	Visual Inspection at the inlet side of the meter-Copper Line	Unknown		Single Family Residence	No	Unknown	No
40960	512 Holdredge	No	No	Unknown - Unlikely Lead	Don't know	1949	3/4"	Other	No	Other		Non-Lead - Copper	1949	3/4"	Other	Yes	Other	8/28/2024	Visual Inspection at the inlet side of the meter-Copper Line	Unknown		Single Family Residence	No	Unknown	No
40970	711 S 6th	No	No	Unknown - Unlikely Lead	Don't know	1953	3/4"	Other	No	Other		Non-Lead - Copper	1953	3/4"	Other	Yes	Other	6/20/2024	Visual Inspection at the inlet side of the meter-Copper Line	Unknown		Single Family Residence	No	Unknown	No
40980	709 S 6th	No	No	Unknown - Unlikely Lead	Don't know	1951	3/4"	Other	No	Other		Non-Lead - Copper	1951	3/4"	Other	Yes	Other	6/24/2024	Visual Inspection at the inlet side of the meter-Copper Line	Unknown		Single Family Residence	No	Unknown	No
40990	707 S 6th	No	No	Unknown - Unlikely Lead	Don't know	1953	3/4"	Other	No	Other		Non-Lead - Copper	1953	3/4"	Other	Yes	Other	6/25/2024	Visual Inspection at the inlet side of the meter-Copper Line	Unknown		Single Family Residence	No	Unknown	No
41000	705 S 6th	No	No	Unknown - Unlikely Lead	Don't know	1953	3/4"	Other	No	Other		Non-Lead - Copper	1953	3/4"	Other	Yes	Other	9/12/2024	Visual Inspection at the inlet side of the meter-Copper Line	Unknown		Single Family Residence	No	Unknown	No
41010	517 Montana	No	No	Unknown - Unlikely Lead	Don't know	1954	3/4"	Other	No	Other		Non-Lead - Copper	1954	3/4"	Other	Yes	Other	8/20/2024	Visual Inspection at the inlet side of the meter-Copper Line	Unknown		Single Family Residence	No	Unknown	No
41040	607 S 6th	No	No	Unknown - Unlikely Lead	Don't know	1920	3/4"	Other	No	Other		Non-Lead - Copper	1920	3/4"	Other	Yes	Other	6/26/2024	Visual Inspection at the inlet side of the meter-Copper Line	Unknown		Single Family Residence	No	Unknown	No
41050	603 S 6th	No	No	Unknown - Unlikely Lead	Don't know	1920	3/4"	Other	No	Other		Non-Lead - Copper	1920	3/4"	Other	Yes	Other	9/17/2024	Visual Inspection at the inlet side of the meter-Copper Line	Unknown		Single Family Residence	No	Unknown	No
41060	601 S 6th	No	No	Unknown - Unlikely Lead	Don't know	1933	3/4"	Other	No	Other		Non-Lead - Copper	1933	3/4"	Other	Yes	Other	8/21/2024	Visual Inspection at the inlet side of the meter-Copper Line	Unknown		Single Family Residence	No	Unknown	No
41070	502 Wyoming Ave	No	No	Unknown - Unlikely Lead	Don't know	1975	3/4"	Other	No	Other		Non-Lead - Copper	1975	3/4"	Other	Yes	Other	10/1/2024	Visual Inspection at the inlet side of the meter-Copper Line	Unknown		Single Family Residence	No	Unknown	No
41090	505 S 6th	No	No	Unknown - Unlikely Lead	Don't know	1910	3/4"	Other	No	Other		Non-Lead - Copper	1910	3/4"	Other	Yes	Other	7/25/2024	Visual Inspection at the inlet side of the meter-Copper Line	Unknown		Single Family Residence	No	Unknown	No
41100	503 S 6th	No	No	Unknown - Unlikely Lead	Don't know	1900	3/4"	Other	No	Other		Non-Lead - Copper	1900	3/4"	Other	Yes	Other	7/31/2024	Visual Inspection at the inlet side of the meter-Copper Line	Unknown		Single Family Residence	No	Unknown	No
41110	501 S 6th	No	No	Unknown - Unlikely Lead	Don't know	1996	3/4"	Other	No	Other		Non-Lead - Plastic	1996	3/4"	Other	Yes	Other	6/21/2024	Visual Inspection at the inlet side of the meter-PVC	Unknown		Single Family Residence	No	Unknown	No
41120	512 Myrtle	No	No	Unknown - Unlikely Lead	Don't know	1908	3/4"	Other	No	Other		Non-Lead - Copper	1908	3/4"	Other	Yes	Other	8/21/2024	Visual Inspection at the inlet side of the meter-Copper Line	Unknown		Single Family Residence	No	Unknown	No
41125	409 S 6th	No	No	Non-Lead - Plastic	Don't know	1994	3/4"	Service line repair or replacement record	No		Records from the Myrtle & N 7th Street Water Line Replacement 1994	Non-Lead - Plastic	2020	3/4"	Other	Yes	Other	6/14/2024	Visual Inspection at the inlet side of the meter-Poly Line	Non-Lead		Single Family Residence	No	Unknown	No
41130	405 S 6th	No	No	Unknown - Unlikely Lead	Don't know	1915	3/4"	Other	No	Other		Non-Lead - Copper	1915	3/4"	Other	Yes	Other	1/23/2024	Visual Inspection at the inlet side of the meter-Copper Line	Unknown		Single Family Residence	No	Unknown	No
41140	403 S 6th	No	No	Unknown - Unlikely Lead	Don't know	1941	3/4"	Other	No	Other		Non-Lead - Copper	1941	3/4"	Other	Yes	Other	7/19/2024	Visual Inspection at the inlet side of the meter-Copper Line	Unknown		Single Family Residence	No	Unknown	No
41150	301 S 6th	No	No	Unknown - Unlikely Lead	Don't know	1900	3/4"	Other	No	Other		Non-Lead - Copper	1900	3/4"	Other	Yes	Other	8/8/2024	Visual Inspection at the inlet side of the meter-Copper Line	Unknown		Single Family Residence	No	Unknown	No
41155	511 West A	No	No	Unknown - Unlikely Lead	Don't know	1953	3/4"	Other	No	Other		Non-Lead - Copper	1953	3/4"	Other	Yes	Other	8/8/2024	Visual Inspection at the inlet side of the meter-Copper Line	Unknown		Single Family Residence	No	Unknown	No
41160	518 West A	No	No	Unknown - Unlikely Lead	Don't know	1939	3/4"	Other	No	Other		Non-Lead - Copper	1939	3/4"	Other	Yes	Other	8/8/2024	Visual Inspection at the inlet side of the meter-Copper Line	Unknown		Single Family Residence	No	Unknown	No
41170	201 S 6th	No	No	Unknown - Unlikely Lead	Don't know	1920	3/4"	Other	No	Other		Non-Lead - Copper	1920	3/4"	Other	Yes	Other	6/17/2024	Visual Inspection at the inlet side of the meter-Copper Line	Unknown		Single Family Residence	No	Unknown	No
41181	514 West B	No	No	Unknown - Unlikely Lead	Don't know	1970	3/4'	Other	No	Other		Non-Lead - Copper	1970	3/4"	Other	Yes	Other	6/24/2024	Visual Inspection at the inet side of the meter-Copper Line	Unknown		Single Family Residence	No	Unknown	No
41190	512 West B	No	No	Unknown - Unlikely Lead	Don't know	1920	3/4"	Other	No	Other		Non-Lead - Copper	1920	3/4"	Other	Yes	Other	2/1/2024	Visual Inspection at the inlet side of the meter-Copper Line	Unknown		Single Family Residence	No	Unknown	No
50010	611 West c	No	No	Unknown - Unlikely Lead	Don't know	1900	3/4"	Other	No	Other		Non-Lead - Copper	1900	3/4"	Other	Yes	Other	6/26/2024	Visual Inspection at the inlet side of the meter-Copper Line	Unknown		Single Family Residence	No	Unknown	No
50020	102 S 6th Street	No	No	Unknown - Unlikely Lead	Don't know	1925	3/4"	Other	No	Other		Non-Lead - Plastic	1925	3/4"	Other	Yes	Customer self-identification	Dec-21	Customer replaced the line from the curbstop to the house in 2021 using poly pipe	Unknown		Single Family Residence	No	Unknown	No
50030	106 S 6th	No	No	Unknown - Unlikely Lead	Don't know	1905	3/4"	Other	No	Other		Non-Lead - Copper	1905	3/4"	Other	Yes	Other	8/21/2024	Visual Inspection at the inlet side of the meter-Copper Line	Unknown		Single Family Residence	No	Unknown	No
50040	108 S 6th	No	No	Unknown - Unlikely Lead	Don't know	1915	3/4"	Other	No	Other		Non-Lead - Copper	1915	3/4"	Other	Yes	Other	6/27/2024	Visual Inspection at the inlet side of the meter-Copper Line	Unknown		Single Family Residence	No	Unknown	No
50050	112 S 6th	No	No	Unknown - Unlikely Lead	Don't know	1940	3/4"	Other	No	Other		Non-Lead - Copper	1940	3/4"	Other	Yes	Other	2/23/2024	Visual Inspection at the inlet side of the meter-Copper Line	Unknown		Single Family Residence	No	Unknown	No
50060	601 West B	No	No	Unknown - Unlikely Lead	Don't know	1910	3/4"	Other	No	Other		Non-Lead - Copper	1910	3/4"	Other	Yes	Other	3/12/2024	Visual Inspection at the inlet side of the meter-Copper Line	Unknown		Single Family Residence	No	Unknown	No
50070	611 West B	No	No	Unknown - Unlikely Lead	Don't know	1946	3/4"	Other	No	Other		Non-Lead - Copper	1946	3/4"	Other	Yes	Other	8/21/2024	Visual Inspection at the inlet side of the meter-Copper Line	Unknown		Single Family Residence	No	Unknown	No
50081	204 S 6th	No	No	Unknown - Unlikely Lead	Don't know	1941	3/4"	Other	No	Other		Non-Lead - Copper	1941	3/4"	Other	Yes	Other	6/25/2024	Visual Inspection at the inlet side of the meter-Copper Line	Unknown		Single Family Residence	No	Unknown	No
50090	208 S 6th	No	No	Unknown - Unlikely Lead	Don't know	1938	3/4"	Other	No	Other		Non-Lead - Copper	1938	3/4"	Other	Yes	Other	9/12/2024	Visual Inspection at the inlet side of the meter-Copper Line	Unknown		Single Family Residence	No	Unknown	No
50100	610 West A	No	No	Unknown - Unlikely Lead	Don't know	1940	3/4"	Other	No	Other		Non-Lead - Copper	1940	3/4"	Other	Yes	Other	9/6/2024	Visual Inspection at the inlet side of the meter-Copper Line	Unknown		Single Family Residence	No	Unknown	No
50110	603 West A	No	No	Unknown - Unlikely Lead	Don't know	1910	3/4"	Other	No	Other		Non-Lead - Copper	1910	3/4"	Other	Yes	Other	6/17/2024	Visual Inspection at the inet side of the meter-Copper Line	Unknown		Single Family Residence	No	Unknown	No
50120	402 S 6th	No	No	Unknown - Unlikely Lead	Don't know	1912	3/4"	Other	No	Other		Non-Lead - Copper	1912	3/4"	Other	Yes	Other	8/1/2024	Visual Inspection at the inlet side of the meter-Copper Line	Unknown		Single Family Residence	No	Unknown	No
50130	408 S 6th	No	No	Unknown - Unlikely Lead	Don't know	1923	3/4"	Other	No	Other		Non-Lead - Copper	1923	3/4"	Other	Yes	Other	8/20/2024	Visual Inspection at the inlet side of the meter-Copper Line	Unknown		Single Family Residence	No	Unknown	No
50150	614 Myrtle	No	No	Unknown - Unlikely Lead	Don't know	1976	3/4"	Other	No	Other		Non-Lead - Copper	1976	3/4"	Other	Yes	Other	6/26/2024	Visual Inspection at the inlet side of the meter-Copper Line	Unknown		Single Family Residence	No	Unknown	No
50160	502 S 6th	No	No	Unknown - Unlikely Lead	Don't know	1920	3/4"	Other	No	Other		Non-Lead - Copper	1920	3/4"	Other	Yes	Other	8/27/2024	Visual Inspection at the inlet side of the meter pit-Copper Line	Unknown		Single Family Residence	No	Unknown	No
50170	506 S 6th	No	No	Unknown - Unlikely Lead	Don't know	1910	3/4"	Other	No	Other		Non-Lead - Copper	1910	3/4"	Other	Yes	Other	2/6/2024	Visual Inspection at the inlet side of the meter-Copper Line	Unknown		Single Family Residence	No	Unknown	No
50190	512 S 6th	No	No	Unknown - Unlikely Lead	Don't know	1910	3/4"	Other	No	Other		Non-Lead - Copper	1910	3/4"	Other	Yes	Other	9/9/2024	Visual Inspection at the inlet side of the meter-Copper Line	Unknown		Single Family Residence	No	Unknown	No
50200	602 S 6th	No	No	Unknown - Unlikely Lead	Don't know	1917	3/4"	Other	No	Other		Non-Lead - Copper	1917	3/4"	Other	Yes	Other	9/6/2024	Visual Inspection at the inlet side of the meter-Copper Line	Unknown		Single Family Residence	No	Unknown	No
50210	606 S 6th	No	No	Unknown - Unlikely Lead	Don't know	1920	3/4"	Other	No	Other		Non-Lead - Copper	1920	3/4"	Other	Yes	Other	8/27/2024	Visual Inspection at the inlet side of the meter-Copper Line	Unknown		Single Family Residence	No	Unknown	No
50220	610 S 6th	No	No	Unknown - Unlikely Lead	Don't know	1900	3/4"	Other	No	Other		Non-Lead - Copper	1900	3/4"	Other	Yes	Other	8/22/2010	Visual Inspection at the inlet side of the meter-Copper Line	Unknown		Single Family Residence	No	Unknown	No
50230	614 S 6th	No	No	Unknown - Unlikely Lead	Don't know	1911	3/4"	Other	No	Other		Non-Lead - Copper	1911	3/4"	Other	Yes	Other	8/1/2024	Visual Inspection at the inlet side of the meter-Copper Line	Unknown		Single Family Residence	No	Unknown	No
50240	601 Montana	No	No	Unknown - Unlikely Lead	Don't know	1980	3/4"	Other	No	Other		Non-Lead - Copper	1980	3/4"	Other	Yes	Other	9/10/2024	Visual Inspection at the inlet side of the meter-Copper Line	Unknown		Single Family Residence	No	Unknown	No
50250	708 S 6th	No	No	Unknown - Unlikely Lead	Don't know	1917	3/4"	Other	No	Other		Non-Lead - Copper	1917	3/4"	Other	Yes	Other	6/28/2024	Visual Inspection at the inlet side of the meter-Copper Line	Unknown		Single Family Residence	No	Unknown	No
50260	710 S 6th			Unknown - Unlikely Lead																Unknown					
50270	602 Holdredge	No	No	Unknown - Unlikely Lead	Don't know	1917	3/4"	Other	No	Other		Non-Lead - Copper	1917	3/4"	Other	Yes	Other	6/19/2024	Visual Inspection at the inlet side of the meter-Copper Line	Unknown		Single Family Residence	No	Unknown	No
50280	707 S 7th	No	No	Unknown - Unlikely Lead	Don't know	1950	3/4"	Other	No	Other		Non-Lead - Copper	1950	3/4"	Other	Yes	Other	6/21/2024	Visual Inspection at the inlet side of the meter-Copper Line	Unknown		Single Family Residence	No	Unknown	No
50290	703 S 7th	No	No	Unknown - Unlikely Lead	Don't know	1951	3/4"	Other	No	Other		Non-Lead - Copper	1951	3/4"	Other	Yes	Other	8/28/2024	Visual Inspection at the inlet side of the meter-Copper Line	Unknown		Single Family Residence	No	Unknown	No
50300	618 Montana	No	No	Unknown - Unlikely Lead	Don't know	1957	3/4"	Other	No	Other		Non-Lead - Copper	1957	3/4"	Other	Yes	Other	9/12/2024	Visual Inspection at the inlet side of the meter-Copper Line	Unknown		Single Family Residence	No	Unknown	No
50310	609 S 7th	No	No	Unknown - Unlikely Lead	Don't know	1957	3/4"	Other	No	Other		Non-Lead - Copper	1915	3/4"	Other	Yes	Other	6/14/2024	Visual Inspection at the inlet side of the meter-Copper Line	Unknown		Single Family Residence	No	Unknown	No
50320	603 S 7th	No	No	Unknown - Unlikely Lead	Don't know	1957	3/4"	Other	No	Other		Non-Lead - Copper	1957	3/4"	Other	Yes	Other	6/18/2024	Visual Inspection at the inlet side of the meter-Copper Line	Unknown		Single Family Residence	No	Unknown	No
50330	610 Wyoming	No	No	Unknown - Unlikely Lead	Don't know	1920	3/4"	Other	No	Other		Non-Lead - Copper	1920	3/4"	Other	Yes	Other	7/5/2024	Visual Inspection at the inlet side of the meter-Copper Line	Unknown		Single Family Residence	No	Unknown	No
50340	507 S 7th	No	No	Unknown - Unlikely Lead	Don't know	1951	3/4"	Other	No	Other		Non-Lead - Copper	1951	3/4"	Other	Yes	Other	9/30/2024	Visual Inspection at the inlet side of the meter-Copper Line	Unknown		Single Family Residence	No	Unknown	No
50350	505 S 7th	No	No	Unknown - Unlikely Lead	Don't know	1950	3/4"	Other	No	Other		Non-Lead - Copper	1950	3/4"	Other	Yes	Other	9/9/2024	Visual Inspection at the inlet side of the meter pit-Copper Line	Unknown		Single Family Residence	No	Unknown	No

Visual Inspection at the

50360	615 Myrtle	No	No	Unknown - Unlikely Lead	Don't know	1910	3/4"	Other	No	Other	Non-Lead - Copper	1910	3/4"	Other	Yes	Other	9/10/2024	inlet side of the meter-pit-Copper Line	Unknown	Single Family Residence	No	Unknown	No
50380	411 S 7th	No	No	Unknown - Unlikely Lead	Don't know	1932	3/4"	Other	No	Other	Non-Lead - Copper	1932	3/4"	Other	Yes	Other	9/5/2024	Visual Inspection at the inlet side of the meter-pit-Copper Line	Unknown	Single Family Residence	No	Unknown	No
50390	409 S 7th	No	No	Unknown - Unlikely Lead	Don't know	1920	3/4"	Other	No	Other	Non-Lead - Copper	1920	3/4"	Other	Yes	Other	2/23/2024	Visual Inspection at the inlet side of the meter-pit-Copper Line	Unknown	Single Family Residence	No	Unknown	No
50400	401 S 7th	No	No	Unknown - Unlikely Lead	Don't know	1952	3/4"	Other	No	Other	Non-Lead - Copper	1952	3/4"	Other	Yes	Other	5/17/2024	Visual Inspection at the inlet side of the meter-pit-Copper Line	Unknown	Single Family Residence	No	Unknown	No
50411	617 West A	No	No	Unknown - Unlikely Lead	Don't know	1916	3/4"	Other	No	Other	Non-Lead - Other	1916	3/4"	Other	Yes	Other		Customer Verification from Water Line Survey-Galvanized	Unknown	Single Family Residence	No	Unknown	No
50420	611 West A	No	No	Unknown - Unlikely Lead	Don't know	1923	3/4"	Other	No	Other	Non-Lead - Copper	1923	3/4"	Other	Yes	Other	6/24/2024	Visual Inspection at the inlet side of the meter-pit-Copper Line	Unknown	Single Family Residence	No	Unknown	No
50430	616 West A	No	No	Unknown - Unlikely Lead	Don't know	1951	3/4"	Other	No	Other	Non-Lead - Copper	1951	3/4"	Other	Yes	Other	6/21/2024	Visual Inspection at the inlet side of the meter-Copper Line	Unknown	Single Family Residence	No	Unknown	No
50440	619 West B	No	No	Unknown - Unlikely Lead	Don't know	1946	3/4"	Other	No	Other	Non-Lead - Copper	1946	3/4"	Other	Yes	Other	8/8/2024	Visual Inspection at the inlet side of the meter-pit-Copper Line	Unknown	Single Family Residence	No	Unknown	No
50450	618 West B	No	No	Unknown - Unlikely Lead	Don't know	1916	3/4"	Other	No	Other	Non-Lead - Copper	1919	3/4"	Other	Yes	Other	8/1/2024	Visual Inspection at the inlet side of the meter-Copper Line	Unknown	Single Family Residence	No	Unknown	No
50460	109 S 7th	No	No	Unknown - Unlikely Lead	Don't know	1980	3/4"	Other	No	Other	Non-Lead - Copper	1980	3/4"	Other	Yes	Other	7/9/2024	Visual Inspection at the inlet side of the meter-pit-Copper Line	Unknown	Single Family Residence	No	Unknown	No
50470	102 S 7th	No	No	Unknown - Unlikely Lead	Don't know	1920	3/4"	Other	No	Other	Non-Lead - Copper	1920	3/4"	Other	Yes	Other	7/12/2024	Visual Inspection at the inlet side of the meter-pit-Copper Line	Unknown	Single Family Residence	No	Unknown	No
50480	104 S 7th	No	No	Unknown - Unlikely Lead	Don't know	1912	3/4"	Other	No	Other	Non-Lead - Copper	1912	3/4"	Other	Yes	Other	6/25/2024	Visual Inspection at the inlet side of the meter-pit-Copper Line	Unknown	Single Family Residence	No	Unknown	No
50490	108 S 7th	No	No	Unknown - Unlikely Lead	Don't know	1978	3/4"	Other	No	Other	Non-Lead - Copper	1978	3/4"	Other	Yes	Other	6/28/2024	Visual Inspection at the inlet side of the meter-pit-Copper Line	Unknown	Single Family Residence	No	Unknown	No
50500	110 S 7th	No	No	Unknown - Unlikely Lead	Don't know	1907	3/4"	Other	No	Other	Non-Lead - Copper	1907	3/4"	Other	Yes	Other	8/12/2024	Visual Inspection at the inlet side of the meter-pit-Copper Line	Unknown	Single Family Residence	No	Unknown	No
50510	204 S 7th	No	No	Unknown - Unlikely Lead	Don't know	1906	3/4"	Other	No	Other	Non-Lead - Copper	1906	3/4"	Other	Yes	Other	7/18/2024	Visual Inspection at the inlet side of the meter-pit-Copper Line	Unknown	Single Family Residence	No	Unknown	No
50520	206 S 7th	No	No	Non-Lead - Copper	Don't know	1994	3/4"	Installation date after lead ban	No	Other	Non-Lead - Copper	1994	3/4"	Other	Yes	Other	7/18/2024	Visual Inspection at the inlet side of the meter-pit-Copper Line	Non-Lead	Single Family Residence	No	Unknown	No
50530	206 S 7th	No	No	Unknown - Unlikely Lead	Don't know	1904	3/4"	Other	No	Other	Non-Lead - Copper	1904	3/4"	Other	Yes	Other	7/22/2024	Visual Inspection at the inlet side of the meter-pit-Copper Line	Unknown	Single Family Residence	No	Unknown	No
50540	702 West A	No	No	Unknown - Unlikely Lead	Don't know	1910	3/4"	Other	No	Other	Non-Lead - Plastic	1910	3/4"	Other	Yes	Other	6/14/2024	Visual Inspection at the inlet side of the meter-pit-Poly Line	Unknown	Single Family Residence	No	Unknown	No
50550	711 West A	No	No	Non-Lead - Plastic	Don't know	2000	3/4"	Installation date after lead ban	No	Other	Non-Lead - Plastic	2000	3/4"	Other	Yes	Other	9/9/2024	Visual Inspection at the inlet side of the meter-Poly Line	Non-Lead	Single Family Residence	No	Unknown	No
50560	302 S 7th	No	No	Non-Lead - Copper	Don't know	1925	3/4"	Other	No	Other	Non-Lead - Copper	1925	3/4"	Other	Yes	Other	6/28/2024	Visual Inspection at the inlet side of the meter-Copper Line	Non-Lead	Single Family Residence	No	Unknown	No
50570	304 S 7th	No	No	Unknown - Unlikely Lead	Don't know	1920	3/4"	Other	No	Other	Non-Lead - Copper	1920	3/4"	Other	Yes	Other	6/25/2024	Visual Inspection at the inlet side of the meter-Copper Line	Unknown	Single Family Residence	No	Unknown	No
50580	402 S 7th	No	No	Unknown - Unlikely Lead	Don't know	1962					Non-Lead - Other	1962	3/4"	Other	Yes	Other	9/1/2024	Customer Verification from Water Line Survey-Brass	Unknown	Single Family Residence	No	Unknown	No
50590	404 S 7th	No	No	Unknown - Unlikely Lead	Don't know	1954	3/4"	Other	No	Other	Non-Lead - Copper	1954	3/4"	Other	Yes	Other	9/25/2024	Visual Inspection at the inlet side of the meter-Copper Line	Unknown	Single Family Residence	No	Unknown	No
50600	410 S 7th	No	No	Unknown - Unlikely Lead	Don't know	1906	3/4"	Other	No	Other	Non-Lead - Copper	1906	3/4"	Other	Yes	Other	6/18/2024	Visual Inspection at the inlet side of the meter-Copper Line	Unknown	Single Family Residence	No	Unknown	No
50610	412 S th	No	No	Unknown - Unlikely Lead	Don't know	1925	3/4"	Other	No	Other	Non-Lead - Copper	1925	3/4"	Other	Yes	Other	6/28/2024	Visual Inspection at the inlet side of the meter-Copper Line	Unknown	Single Family Residence	No	Unknown	No
50620	502 S 7th	No	No	Unknown - Unlikely Lead	Don't know	1935	3/4"	Other	No	Other	Non-Lead - Copper	1935	3/4"	Other	Yes	Other	9/5/2024	Visual Inspection at the inlet side of the meter-Copper Line	Unknown	Single Family Residence	No	Unknown	No
50630	504 S 7th	No	No	Unknown - Unlikely Lead	Don't know	1925	3/4"	Other	No	Other	Non-Lead - Copper	1925	3/4"	Other	Yes	Other	6/18/2024	Visual Inspection at the inlet side of the meter-Copper Line	Unknown	Single Family Residence	No	Unknown	No
50640	508 S 7th	No	No	Unknown - Unlikely Lead	Don't know	1951	3/4"	Other	No	Other	Non-Lead - Copper	1951	3/4"	Other	Yes	Other	6/20/2024	Visual Inspection at the inlet side of the meter-Copper Line	Unknown	Single Family Residence	No	Unknown	No
50650	710 Wyoming	No	No	Unknown - Unlikely Lead	Don't know	1975	3/4"	Other	No	Other	Non-Lead - Copper	1975	3/4"	Other	Yes	Other	7/8/2024	Visual Inspection at the inlet side of the meter-Copper Line	Unknown	Single Family Residence	No	Unknown	No
50660	602 S 7th	No	No	Unknown - Unlikely Lead	Don't know	1917	3/4"	Other	No	Other	Non-Lead - Copper	1917	3/4"	Other	Yes	Other	8/1/2024	Visual Inspection at the inlet side of the meter-Copper Line	Unknown	Single Family Residence	No	Unknown	No
50670	604 S 7th	No	No	Unknown - Unlikely Lead	Don't know	1979	3/4"	Other	No	Other	Non-Lead - Copper	1979	3/4"	Other	Yes	Other	7/1/2024	Visual Inspection at the inlet side of the meter-Copper Line	Unknown	Single Family Residence	No	Unknown	No
50680	608 S 7th	No	No	Unknown - Unlikely Lead	Don't know	1930	3/4"	Other	No	Other	Non-Lead - Copper	1930	3/4"	Other	Yes	Other	6/25/2024	Visual Inspection at the inlet side of the meter-Copper Line	Unknown	Single Family Residence	No	Unknown	No
50690	610 S 7th	No	No	Unknown - Unlikely Lead	Don't know	1917	3/4"	Other	No	Other	Non-Lead - Copper	1917	3/4"	Other	Yes	Other	6/25/2024	Visual Inspection at the inlet side of the meter-Copper Line	Unknown	Single Family Residence	No	Unknown	No
50700	702 S 7th	No	No	Unknown - Unlikely Lead	Don't know	1917	3/4"	Other	No	Other	Non-Lead - Copper	1917	3/4"	Other	Yes	Other	9/20/2024	Visual Inspection at the inlet side of the meter-Copper Line	Unknown	Single Family Residence	No	Unknown	No
50710	706 S 7th	No	No	Unknown - Unlikely Lead	Don't know	1921	3/4"	Other	No	Other	Non-Lead - Copper	1921	3/4"	Other	Yes	Other	9/17/2024	Visual Inspection at the inlet side of the meter-Copper Line	Unknown	Single Family Residence	No	Unknown	No
50715	704 Holdredge	No	No	Non-Lead - Plastic	Don't know	2017	3/4"	Installation date after lead ban	No	Other	Non-Lead - Plastic	2017	3/4"	Other	Yes	Other	6/14/2024	Visual Inspection at the inlet side of the meter-Pex Line	Non-Lead	Single Family Residence	No	Unknown	No
50720	711 S 8th	No	No	Unknown - Unlikely Lead	Don't know	1940	3/4"	Other	No	Other	Non-Lead - Copper	1940	3/4"	Other	Yes	Other	3/6/2024	Visual Inspection at the inlet side of the meter-Copper Line	Unknown	Single Family Residence	No	Unknown	No
50730	709 S 8th	No	No	Unknown - Unlikely Lead	Don't know	1940	3/4"	Other	No	Other	Non-Lead - Copper	1940	3/4"	Other	Yes	Other	3/7/2024	Visual Inspection at the inlet side of the meter-Copper Line	Unknown	Single Family Residence	No	Unknown	No
50735	707 S 8th	No	No	Unknown - Unlikely Lead	Don't know	1940	3/4"	Other	No	Other	Non-Lead - Copper	1940	3/4"	Other	Yes	Other	12/14/2023	Visual Inspection at the inlet side of the meter-Copper Line	Unknown	Single Family Residence	No	Unknown	No
50750	705 S 8th	No	No	Unknown - Unlikely Lead	Don't know	1940	3/4"	Other	No	Other	Non-Lead - Copper	1940	3/4"	Other	Yes	Other	9/4/2024	Visual Inspection at the inlet side of the meter-Copper Line	Unknown	Single Family Residence	No	Unknown	No
50755	703 S 8th	No	No	Unknown - Unlikely Lead	Don't know	1974	3/4"	Other	No	Other	Non-Lead - Copper	1974	3/4"	Other	Yes	Other	6/27/2024	Visual Inspection at the inlet side of the meter-Copper Line	Unknown	Single Family Residence	No	Unknown	No
50760	719 Montana	No	No	Unknown - Unlikely Lead	Don't know	1930	3/4"	Other	No	Other	Non-Lead - Copper	1930	3/4"	Other	Yes	Other	9/5/2024	Visual Inspection at the inlet side of the meter-Copper Line	Unknown	Single Family Residence	No	Unknown	No
50770	607 8th	No	No	Unknown - Unlikely Lead	Don't know	1950	3/4"	Other	No	Other	Non-Lead - Copper	1950	3/4"	Other	Yes	Other	8/23/2024	Visual Inspection at the inlet side of the meter-Copper Line	Unknown	Single Family Residence	No	Unknown	No
50780	601 S 8th	No	No	Unknown - Unlikely Lead	Don't know	1975	3/4"	Other	No	Other	Non-Lead - Copper	1975	3/4"	Other	Yes	Other	8/23/2024	Visual Inspection at the inlet side of the meter-Copper Line	Unknown	Single Family Residence	No	Unknown	No
50790	511 S 8th	No	No	Unknown - Unlikely Lead	Don't know	1987	3/4"	Other	No	Other	Non-Lead - Copper	1987	3/4"	Other	Yes	Other	6/17/2024	Visual Inspection at the inlet side of the meter-Copper Line	Unknown	Single Family Residence	No	Unknown	No
50800	713 Myrtle	No	No	Unknown - Unlikely Lead	Don't know	1908	3/4"	Other	No	Other	Non-Lead - Copper	1908	3/4"	Other	Yes	Other	8/21/2024	Visual Inspection at the inlet side of the meter-Copper Line	Unknown	Single Family Residence	No	Unknown	No
50810	719 Myrtle	No	No	Unknown - Unlikely Lead	Don't know	1915	3/4"	Other	No	Other	Non-Lead - Copper	1915	3/4"	Other	Yes	Other	8/21/2024	Visual Inspection at the inlet side of the meter-Copper Line	Unknown	Single Family Residence	No	Unknown	No
50815	714 Myrtle	No	No	Non-Lead - Copper	Don't know	2003	3/4"	Installation date after lead ban	No	Other	Non-Lead - Copper	2003	3/4"	Installation date after lead ban	Yes	Other	6/17/2024	Visual Inspection at the inlet side of the meter-Copper Line	Non-Lead	Single Family Residence	No	Unknown	No
50820	405 S 8th	No	No	Unknown - Unlikely Lead	Don't know	1905	3/4"	Other	No	Other	Non-Lead - Copper	1905	3/4"	Other	Yes	Other	6/25/2024	Visual Inspection at the inlet side of the meter-Copper Line	Unknown	Single Family Residence	No	Unknown	No
50830	401 S 8th	No	No	Unknown - Unlikely Lead	Don't know	1945	3/4"	Other	No	Other	Non-Lead - Copper	1945	3/4"	Other	Yes	Other	6/25/2024	Visual Inspection at the inlet side of the meter-Copper Line	Unknown	Single Family Residence	No	Unknown	No
50850	716 West A	No	No	Unknown - Unlikely Lead	Don't know	1920	3/4"	Other	No	Other	Non-Lead - Copper	1920	3/4"	Other	Yes	Other	7/22/2024	Visual Inspection at the inlet side of the meter-Copper Line	Unknown	Single Family Residence	No	Unknown	No
50860	205 S 8th	No	No	Unknown - Unlikely Lead	Don't know	1950	3/4"	Other	No	Other	Non-Lead - Copper	1950	3/4"	Other	Yes	Other	9/11/2024	Visual Inspection at the inlet side of the meter-Copper Line	Unknown	Single Family Residence	No	Unknown	No
50870	719 West B	No	No	Unknown - Unlikely Lead	Don't know	1960	3/4"	Other	No	Other	Non-Lead - Copper	1960	3/4"	Other	Yes	Other	6/24/2024	Visual Inspection at the inlet side of the meter-Copper Line	Unknown	Single Family Residence	No	Unknown	No
50880	712 West B	No	No	Unknown - Unlikely Lead	Don't know	1920	3/4"	Other	No	Other	Non-Lead - Copper	1920	3/4"	Other	Yes	Other	6/20/2024	Visual Inspection at the inlet side of the meter-Copper Line	Unknown	Single Family Residence	No	Unknown	No
50890	109 S 8th	No	No	Unknown - Unlikely Lead	Don't know	1946	3/4"	Other	No	Other	Non-Lead - Copper	1946	3/4"	Other	Yes	Other	6/24/2024	Visual Inspection at the inlet side of the meter-Copper Line	Unknown	Single Family Residence	No	Unknown	No
50900	107 S 8th	No	No	Unknown - Unlikely Lead	Don't know	1915	3/4"	Other	No	Other	Non-Lead - Copper	1915	3/4"	Other	Yes	Other	6/21/2024	Visual Inspection at the inlet side of the meter-Copper Line	Unknown	Single Family Residence	No	Unknown	No
50910	717 West C	No	No	Unknown - Unlikely Lead	Don't know	1904	3/4"	Other	No	Other	Non-Lead - Copper	1904	3/4"	Other	Yes	Other	8/8/2024	Visual Inspection at the inlet side of the meter-Copper Line	Unknown	Single Family Residence	No	Unknown	No
60010	102 S 8th	No	No	Unknown - Unlikely Lead	Don't know	1917	3/4"	Other	No	Other	Non-Lead - Copper	1917	3/4"	Other	Yes	Other	8/7/2024	Visual Inspection at the inlet side of the meter-Copper Line	Unknown	Single Family Residence	No	Unknown	No
60020	106 S 8th	No	No	Unknown - Unlikely Lead	Don't know	1941	3/4"	Other	No	Other	Non-Lead - Copper	1941	3/4"	Other	Yes	Other	8/7/2024	Visual Inspection at the inlet side of the meter-Copper Line	Unknown	Single Family Residence	No	Unknown	No
60030	810 West B	No	No	Unknown - Unlikely Lead	Don't know	1953	3/4"	Other	No	Other	Non-Lead - Copper	1953	3/4"	Other	Yes	Other	9/20/2024	Visual Inspection at the inlet side of the meter-Copper Line	Unknown	Single Family Residence	No	Unknown	No
60040	804 West B	No	No	Unknown - Unlikely Lead	Don't know	1906	3/4"	Other	No	Other	Non-Lead - Copper	1906	3/4"	Other	Yes	Other	7/16/2024	Visual Inspection at the inlet side of the meter-Copper Line	Unknown	Single Family Residence	No	Unknown	No
60050	202 S 8th	No	No	Unknown - Unlikely Lead	Don't know	1906	3/4"	Other	No	Other	Non-Lead - Copper	1906	3/4"	Other	Yes	Other	8/6/2024	Visual Inspection at the inlet side of the meter-Copper Line	Unknown	Single Family Residence	No	Unknown	No

60060	206 S 8th		No	No	Unknown - Unlikely Lead	Don't know	1950	3/4"	Other	No	Other				Non-Lead - Copper	1950	3/4"	Other	Yes	Other	8/8/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No
60070	208 S 8th		No	No	Unknown - Unlikely Lead	Don't know	1981	3/4"	Other	No	Other				Non-Lead - Copper	1981	3/4"	Other	Yes	Other	7/16/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No
60090	210 S 8th		No	No	Unknown - Unlikely Lead	Don't know	1935	3/4"	Other	No	Other				Non-Lead - Copper	1935	3/4"	Other	Yes	Other	8/8/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No
60100	814 West A		No	No	Unknown - Unlikely Lead	Don't know	1920	3/4"	Other	No	Other				Non-Lead - Copper	1920	3/4"	Other	Yes	Other	7/18/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No
60110	803 West A		No	No	Unknown - Unlikely Lead	Don't know	1950	3/4"	Other	No	Other				Non-Lead - Copper	1950	3/4"	Other	Yes	Other	7/19/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No
60120	811 West A		No	No	Unknown - Unlikely Lead	Don't know	1928	3/4"	Other	No	Other				Lead	1928	3/4"	Other	Yes	Other	7/25/2024	Visual inspection at the inlet side of the meter- Lead Line	Lead		Single Family Residence	No	Unknown	No
60130	402 S 8th		No	No	Unknown - Unlikely Lead	Don't know	1920																Unknown					
60140	404 S 8th		No	No	Unknown - Unlikely Lead	Don't know	1909	3/4"	Other	No	Other				Non-Lead - Copper	1909	3/4"	Other	Yes	Other	7/22/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No
60150	408 S 8th		No	No	Unknown - Unlikely Lead	Don't know	1910	3/4"	Other	No	Other				Non-Lead - Copper	1910	3/4"	Other	Yes	Other	7/18/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No
60170	412 S 8th		No	No	Unknown - Unlikely Lead	Don't know	1917	3/4"	Other	No	Other				Non-Lead - Copper	1917	3/4"	Other	Yes	Other	8/13/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No
60180	502 S 8th		No	No	Unknown - Unlikely Lead	Don't know	1917	3/4"	Other	No	Other				Non-Lead - Copper	1917	3/4"	Other	Yes	Customer self-identification	8/1/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No
60190	506 S 8th		No	No	Unknown - Unlikely Lead	Don't know	1912	3/4"	Other	No	Other				Non-Lead - Copper	1912	3/4"	Other	Yes	Other	7/19/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No
60200	508 S 8th		No	No	Unknown - Unlikely Lead	Don't know	1915	3/4"	Other	No	Other				Non-Lead - Copper	1915	3/4"	Other	Yes	Other	8/9/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No
60210	810 Wyoming		No	No	Unknown - Unlikely Lead	Don't know	1908	3/4"	Other	No	Other				Non-Lead - Copper	1908	3/4"	Other	Yes	Other	8/26/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No
60220	602 S 8th		No	No	Non-Lead - Copper		1920	3/4"	Other	No	Other			Mechanical Excavation. Copper Line from water main to curbstop. 10/8/2024.	Non-Lead - Copper	1920	3/4"	Other	Yes	Other	8/16/2024	Visual inspection at the inlet side of the meter- Copper Line	Non-Lead		Single Family Residence	No	Unknown	No
60230	610 S 8th		No	No	Unknown - Unlikely Lead	Don't know	1917	3/4"	Other	No	Other				Non-Lead - Copper	1917	3/4"	Other	Yes	Other	7/29/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No
60240	612 S 8th		No	No	Unknown - Unlikely Lead	Don't know	1918	3/4"	Other	No	Other				Non-Lead - Copper	1918	3/4"	Other	Yes	Other	7/19/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No
60250	702 S 8th		No	No	Unknown - Unlikely Lead	Don't know	1920	3/4"	Other	No	Other				Non-Lead - Copper	1920	3/4"	Other	Yes	Other	7/29/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No
60270	706 S 8th		No	No	Non-Lead - Plastic	Don't know	1999	3/4"	Installation date after lead ban	No	Other				Non-Lead - Plastic	1999	3/4"	Installation date after lead ban					Non-Lead					
60300	710 S 8th		No	No	Non-Lead - Other	Don't know	1997	3/4"	Installation date after lead ban	No	Other				Non-Lead - Other	1997	3/4"	Other	Yes	Other	7/26/2024	Visual inspection at the inlet side of the meter- Stainless Steel	Non-Lead		Single Family Residence	No	Unknown	No
60310	712 S 8th		No	No	Unknown - Unlikely Lead	Don't know	1974	3/4"	Other	No	Other				Non-Lead - Copper	1974	3/4"	Other	Yes	Other	9/11/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No
60315	820 Holdredge Avenue		No	No	Non-Lead - Copper	Don't know	2002	3/4"	Installation date after lead ban	No	Other				Non-Lead - Copper	2002	3/4"	Installation date after lead ban	Yes	Other	1/8/2024	Visual inspection at the inlet side of the meter- Copper Line	Non-Lead		Single Family Residence	No	Unknown	No
60320	819 Montana		No	No	Unknown - Unlikely Lead	Don't know	1972	3/4"	Other	No	Other				Non-Lead - Copper	1972	3/4"	Other	Yes	Other	9/3/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No
60330	818 Montana		No	No	Unknown - Unlikely Lead	Don't know	1954	3/4"	Other	No	Other				Non-Lead - Copper	1954	3/4"	Other	Yes	Other	7/16/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No
60350	605 S 9th		No	No	Unknown - Unlikely Lead	Don't know	1960	3/4"	Other	No	Other				Non-Lead - Plastic	1960	3/4"	Other	Yes	Other	9/3/2024	Visual inspection at the inlet side of the meter- PVC	Unknown		Single Family Residence	No	Unknown	No
60360	817 Wyoming		No	No	Unknown - Unlikely Lead	Don't know	1920	3/4"	Other	No	Other				Non-Lead - Copper	1920	3/4"	Other	Yes	Other	7/26/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No
60370	815 Wyoming		No	No	Unknown - Unlikely Lead	Don't know	1957	3/4"	Other	No	Other												Unknown					
60380	509 S 9th		No	No	Unknown - Unlikely Lead	Don't know	1958	3/4"	Other	No	Other				Non-Lead - Copper	1958	3/4"	Other	Yes	Other	7/17/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No
60390	512 S 9th		No	No	Unknown - Unlikely Lead	Don't know	1952	3/4"	Other	No	Other				Non-Lead - Copper	1952	3/4"	Other	Yes	Other	8/23/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No
60400	508 S 9th		No	No	Unknown - Unlikely Lead	Don't know	1955	3/4"	Other	No	Other				Non-Lead - Copper	1955	3/4"	Other	Yes	Other	7/26/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No
60410	506 S 9th		No	No	Unknown - Unlikely Lead	Don't know	1962	3/4"	Other	No	Other				Non-Lead - Copper	1962	3/4"	Other	Yes	Other	7/26/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No
60420	502 S 9th		No	No	Unknown - Unlikely Lead	Don't know	1959	3/4"	Other	No	Other				Non-Lead - Copper	1959	3/4"	Other	Yes	Other	7/16/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No
60430	818 Myrtle		No	No	Unknown - Unlikely Lead	Don't know	1954	3/4"	Other	No	Other				Non-Lead - Copper	1954	3/4"	Other	Yes	Other	8/12/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No
60440	409 S 9th		No	No	Unknown - Unlikely Lead	Don't know	1957	3/4"	Other	No	Other				Non-Lead - Copper	1957	3/4"	Other	Yes	Other	7/22/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No
60450	407 S 9TH		No	No	Unknown - Unlikely Lead	Don't know	1968	3/4"	Other	No	Other				Non-Lead - Copper	1968	3/4"	Other	Yes	Other	9/3/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No
60460	815 West A		No	No	Unknown - Unlikely Lead	Don't know	1923	3/4"	Other	No	Other				Non-Lead - Copper	1923	3/4"	Other	Yes	Other	7/25/2023	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No
60470	816 West A		No	No	Unknown - Unlikely Lead	Don't know	2001	3/4"	Installation date after lead ban	No	Other				Non-Lead - Plastic	2001	3/4"	Other	Yes	Other	7/18/2024	Visual inspection at the inlet side of the meter- Poly Line	Unknown		Single Family Residence	No	Unknown	No
60480	207 S 9th		No	No	Unknown - Unlikely Lead	Don't know	1949	3/4"	Other	No	Other				Non-Lead - Copper	1949	3/4"	Other	Yes	Other	10/2/2024	Customer Verification- Big Horn Co School District #4-Copper Line	Unknown		Building	No	Unknown	No
60490	813 West B		No	No	Unknown - Unlikely Lead	Don't know	1920	3/4"	Other	No	Other				Non-Lead - Copper	1920	3/4"	Other	Yes	Other	7/17/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No
60500	818 West B		No	No	Unknown - Unlikely Lead	Don't know	1930	3/4"	Other	No	Other				Non-Lead - Copper	1930	3/4"	Other	Yes	Other	8/7/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No
60510	110 S 9th		No	No	Unknown - Unlikely Lead	Don't know	1930	3/4"	Other	No	Other				Non-Lead - Copper	1930	3/4"	Other	Yes	Other	7/23/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No
60520	908 West B		No	No	Unknown - Unlikely Lead	Don't know	1972	3/4"	Other	No	Other				Non-Lead - Copper	1972	3/4"	Other	Yes	Other	7/1/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No
60530	910 West B		No	No	Unknown - Unlikely Lead	Don't know	1950	3/4"	Other	No	Other				Non-Lead - Copper	1950	3/4"	Other	Yes	Other	7/29/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No
60540	1002 West B		No	No	Unknown - Unlikely Lead	Don't know	1955	3/4"	Other	No	Other				Non-Lead - Copper	1955	3/4"	Other	Yes	Other	6/20/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No
60570	108 S 10th		No	No	Unknown - Unlikely Lead	Don't know	1973	3/4"	Other	No	Other				Non-Lead - Copper	1973	3/4"	Other	Yes	Other	8/7/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No
60600	102 S 10th		No	No	Unknown - Unlikely Lead	Don't know	1979	3/4"	Other	No	Other				Non-Lead - Copper	1979	3/4"	Other	Yes	Other	8/7/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No
60605	103 S 10th		No	No	Non-Lead - Plastic	Don't know	2005	3/4"	Installation date after lead ban	No	Other				Non-Lead - Plastic	2005	3/4"	Installation date after lead ban	Yes	Other	7/30/2024	visual inspection at the inlet side of the meter- Poly Line	Unknown		Single Family Residence	No	Unknown	No
60610	101 S 10th		No	No	Unknown - Unlikely Lead	Don't know	1957	3/4"	Other	No	Other				Non-Lead - Copper	1957	3/4"	Other	Yes	Other	7/31/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No
60620	106 S 9th		No	No	Unknown - Unlikely Lead	Don't know	1981	3/4"	Other	No	Other				Non-Lead - Copper	1981	3/4"	Other	Yes	Other	1/26/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No
60630	105 S 9th		No	No	Unknown - Unlikely Lead	Don't know	1977	3/4"	Other	No	Other				Non-Lead - Copper	1977	3/4"	Other	Yes	Other	7/17/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No
60640	817 West C		No	No	Unknown - Unlikely Lead	Don't know	1937	3/4"	Other	No	Other				Non-Lead - Copper	1937	3/4"	Other	Yes	Other	8/7/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No
60650	813 West C		No	No	Unknown - Unlikely Lead	Don't know	1941	3/4"	Other	No	Other				Non-Lead - Copper	1941	3/4"	Other	Yes	Other	7/16/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No
60660	519 West C		No	No	Non-Lead - Copper	Don't know	1990	3/4"	Service line repair or replacement record	No			Records/Map from 1990-State Highway Basin/Burlington Road Big Horn County		Non-Lead - Copper	1965	3/4"	Other	Yes	Other	8/29/2024	Visual inspection at the inlet side of the meter- Copper Line	Non-Lead		Single Family Residence	No	Unknown	No
60670	517 West C		No	No	Unknown - Unlikely Lead	Don't know	1965	3/4"	Other	No	Other				Non-Lead - Copper	1965	3/4"	Other	Yes	Other	2/1/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No
60680	511 West C		No	No	Non-Lead - Copper	Don't know	1990	3/4"	Service line repair or replacement record	No			Records/Map from 1990-State Highway Basin/Burlington Road Big Horn County		Non-Lead - Copper	1973	3/4"	Other	Yes	Other	7/22/2024	Visual inspection at the inlet side of the meter- Copper Line	Non-Lead		Single Family Residence	No	Unknown	No
70005	1800 West B		No	No	Unknown - Unlikely Lead	Don't know	1974	3/4"	Other	No	Other				Non-Lead - Plastic	1980	3/4"	Other	Yes	Other	8/15/2024	Visual inspection at the inlet side of the meter- Poly Line	Unknown		Single Family Residence	No	Unknown	No
70010	1010 West B		No	No	Unknown - Unlikely Lead	Don't know	1980	3/4"	Other	No	Other				Non-Lead - Copper	1980	3/4"	Other	Yes	Other	9/12/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No
70020	TOB-Boiler Room		No	No	Unknown - Unlikely Lead	Don't know	1950	3"	Service line diameter is > 2 inches	No	Other				Non-Lead - Copper	1950	1.5"	Other	Yes	Other	12/8/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No
70030	TOB-Comm Complex		No	No	Unknown - Unlikely Lead	Don't know	1950	1.5"	Other	No	Other				Non-Lead - Copper	1950	1.5"	Other	Yes	Other	12/8/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No
70040	TOB-Gym		No	No	Unknown - Unlikely Lead	Don't know	1950	2"	Other	No	Other				Non-Lead - Copper	1950	2"	Other	Yes	Other	12/8/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No
70050	School District #4 Shop/Football Field		No	No	Unknown - Unlikely Lead	Don't know	1950	1.5"	Other	No	Other				Non-Lead - Copper	1950	1.5"	Other	Yes	Other	7/18/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No
70060	303 Crescent	House/Shop Built in 2023/2024	No	No	Non-Lead - Plastic	Don't know	7/18/2024	3/4"	Service line repair or replacement record	Yes	Visual inspection at the meter pit	7/18/2024	Public Works installed a new meter pit. Mechanical excavation was required to dig up the curbstop and attach CTS pipe to the meter pit.		Non-Lead - Plastic	2024	3/4"	Service line repair or replacement record	Yes	Mechanical excavation at one location	7/18/2024	Installed a new meter pit. Plastic Pipe was installed on the outlet side of the meter pit by the customers plumber.	Non-Lead		Single Family Residence	No	Unknown	No

70060	303 Crescent	No	No	Unknown - Unlikely Lead	Don't know	1957	3/4"	Other	No	Other		Non-Lead - Copper	1957	3/4"	Other	Yes	Other	8/8/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No
70080	212 S 12th	No	No	Unknown - Unlikely Lead	Don't know	1945	3/4"	Other	No	Other		Non-Lead - Copper	1945	3/4"	Other	Yes	Other	8/8/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No
70090	303 S 12th	No	No	Unknown - Unlikely Lead	Don't know	1930	3/4"	Other	No	Other		Non-Lead - Copper	1930	3/4"	Other	Yes	Other	7/22/2024	Visual inspection at the inlet side of the meter- Copper line	Unknown		Single Family Residence	No	Unknown	No
70100	307 Crescent	No	No	Unknown - Unlikely Lead	Don't know	1950	3/4"	Other	No	Other		Non-Lead - Copper	1950	3/4"	Other	Yes	Other	7/19/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No
70110	309 Crescent	No	No	Unknown - Unlikely Lead	Don't know	1920	3/4"	Other	No	Other		Non-Lead - Copper	1920	3/4"	Other	Yes	Other	7/24/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No
70120	401 Crescent	No	No	Unknown - Unlikely Lead	Don't know	1981	3/4"	Other	No	Other		Non-Lead - Copper	1981	3/4"	Other	Yes	Other	7/22/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No
70132	403 Crescent	No	No	Unknown - Unlikely Lead	Don't know	1955	1"	Other	No	Other		Non-Lead - Copper	1955	1"	Other	Yes	Other	7/19/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No
70140	405 Crescent	No	No	Unknown - Unlikely Lead	Don't know	1960	3/4"	Other	No	Other		Non-Lead - Copper	1960	3/4"	Other	Yes	Other	8/2/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No
70150	407 Crescent	No	No	Unknown - Unlikely Lead	Don't know	1972	1.5"	Other	No	Other		Non-Lead - Copper	1972	1.5"	Other	Yes	Other	7/24/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No
70160	304 Crescent	No	No	Unknown - Unlikely Lead	Don't know	1961	3/4"	Other	No	Other		Non-Lead - Copper	1961	3/4"	Other	Yes	Other	7/18/2024	Visual inspection at the inlet side of the meter- Copper line	Unknown		Single Family Residence	No	Unknown	No
70170	306 Crescent	No	No	Unknown - Unlikely Lead	Don't know	1954	3/4"	Other	No	Other		Non-Lead - Copper	1954	3/4"	Other	Yes	Other	7/19/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No
70180	308 Crescent	No	No	Non-Lead - Plastic			3/4"	Other	No	Other	Mechanical Excavation on 10/10/2024. Work Order # 10154. 3/4" CTS Pipe.	Non-Lead - Copper	1969	3/4"	Other	Yes	Other	7/19/2024	Visual inspection at the inlet side of the meter- Copper line	Non-Lead		Single Family Residence	No	Unknown	No
70190	310 Crescent	No	No	Unknown - Unlikely Lead	Don't know	1970	3/4"	Other	No	Other		Non-Lead - Copper	1970	3/4"	Other	Yes	Other	9/12/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No
70200	312 Crescent	No	No	Unknown - Unlikely Lead	Don't know	1950	3/4"	Other	No	Other		Non-Lead - Copper	1950	3/4"	Other	Yes	Other	8/30/2024	Visual inspection at the inlet side of the meter- Copper line	Unknown		Single Family Residence	No	Unknown	No
70210	409 Crescent	No	No	Unknown - Unlikely Lead	Don't know	1972	3/4"	Other	No	Other		Non-Lead - Copper	1972	3/4"	Other	Yes	Other	8/6/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No
70220	618 S 9th	No	No	Unknown - Unlikely Lead	Don't know	1905	3/4"	Other	No	Other		Non-Lead - Copper	1905	3/4"	Other	Yes	Other	7/24/2024	Visual inspection at the inlet side of the meter- Copper line	Unknown		Single Family Residence	No	Unknown	No
70230	704 S 9th	No	No	Non-Lead - Copper	Don't know	1996	3/4"	Installation date after lead ban	No	Other		Non-Lead - Copper	1996	3/4"	Installation date after lead ban	Yes	Other	7/24/2024	Visual inspection at the inlet side of the meter- Copper Line	Non-Lead		Single Family Residence	No	Unknown	No
70240	1 Mountain Road	No	No	Unknown - Unlikely Lead	Don't know	1955	3/4"	Other	No	Other		Non-Lead - Copper	1955	3/4"	Other	Yes	Other	8/9/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No
70250	5 Willow Drive	No	No	Unknown - Unlikely Lead	Don't know	1979	3/4"	Other	No	Other		Non-Lead - Copper	1979	3/4"	Other	Yes	Other	7/17/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No
70260	7 Willow Drive	No	No	Unknown - Unlikely Lead	Don't know	1981	3/4"	Other	No	Other		Non-Lead - Copper	1981	3/4"	Other	Yes	Other	7/19/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No
70270	9 Willow Drive	No	No	Unknown - Unlikely Lead	Don't know	1978	3/4"	Other	No	Other		Non-Lead - Copper	1978	3/4"	Other	Yes	Other	7/17/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No
70280	11 Willow Drive	No	No	Unknown - Unlikely Lead	Don't know	1979	3/4"	Other	No	Other		Non-Lead - Copper	1979	3/4"	Other	Yes	Other	8/22/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No
70285	13 Willow Drive	No	No	Non-Lead - Plastic	Don't know	1998	3/4"	Installation date after lead ban	No	Other		Non-Lead - Plastic	1996	3/4"	Other	Yes	Other	7/17/2024	Visual inspection at the inlet side of the meter- Poly Line	Non-Lead		Single Family Residence	No	Unknown	No
70290	6 Big B Drive	No	No	Unknown - Unlikely Lead	Don't know	1980	3/4"	Other	No	Other		Non-Lead - Copper	1980	3/4"	Other	Yes	Other	8/8/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No
70295	4 Big B Drive	No	No	Non-Lead - Plastic	Don't know	2010	3/4"	Installation date after lead ban	No	Other		Non-Lead - Plastic	2010	3/4"	Other	Yes	Other	8/8/2024	Visual inspection at the inlet side of the meter- Poly Line	Non-Lead		Single Family Residence	No	Unknown	No
70300	8 Big B Drive	No	No	Unknown - Unlikely Lead	Don't know	1980	3/4"	Other	No	Other		Non-Lead - Copper	1980	3/4"	Other	Yes	Other	7/24/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No
70310	1020 Crest	No	No	Unknown - Unlikely Lead	Don't know	1979	3/4"	Other	No	Other		Non-Lead - Copper	1979	3/4"	Other	Yes	Other	8/6/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No
70320	1004 Crest	No	No	Unknown - Unlikely Lead	Don't know	1982	3/4"	Other	No	Other		Non-Lead - Copper	1982	3/4"	Other	Yes	Other	8/12/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No
70330	802 S 9th	No	No	Non-Lead - Copper	Don't know	1988	3/4"	Installation date after lead ban	No	Other		Non-Lead - Copper	1988	3/4"	Installation date after lead ban	Yes	Other	8/2/2024	Visual inspection at the inlet side of the meter- Copper Line	Non-Lead		Single Family Residence	No	Unknown	No
70340	804 S 9th	No	No	Unknown - Unlikely Lead	Don't know	1930	3/4"	Other	No	Other		Non-Lead - Copper	1930	3/4"	Other	Yes	Other	7/30/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No
70360	806 S 9th	No	No	Unknown - Unlikely Lead	Don't know	1920	3/4"	Other	No	Other		Non-Lead - Copper	1920	3/4"	Other	Yes	Other	8/1/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No
70380	905 S 9th	No	No	Unknown - Unlikely Lead	Don't know	1959	3/4"	Other	No	Other		Non-Lead - Copper	1959	3/4"	Other	Yes	Other	7/24/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No
70390	907 S 9th	No	No	Unknown - Unlikely Lead	Don't know	1972	3/4"	Other	No	Other		Non-Lead - Copper	1972	3/4"	Other	Yes	Other	8/28/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No
70400	909 S 9th	No	No	Unknown - Unlikely Lead	Don't know	1981	3/4"	Other	No	Other		Non-Lead - Copper	1981	3/4"	Other	Yes	Other	7/24/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No
70410	911 S 9th	No	No	Unknown - Unlikely Lead	Don't know	1974	3/4"	Other	No	Other		Non-Lead - Copper	1974	3/4"	Other	Yes	Other	7/18/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No
70413	915 S 9th	No	No	Non-Lead - Plastic	Don't know	2007	3/4"	Installation date after lead ban	No	Other		Non-Lead - Plastic	2007	3/4"	Installation date after lead ban	Yes	Other	8/9/2024	Visual inspection at the inlet side of the meter- Poly Line	Non-Lead		Single Family Residence	No	Unknown	No
70415	807 Willow Drive	No	No	Non-Lead - Plastic	Don't know	1996	3/4"	Installation date after lead ban	No	Other		Non-Lead - Plastic	1996	3/4"	Installation date after lead ban	Yes	Other	8/30/2024	Visual inspection at the inlet side of the meter- Poly Line	Non-Lead		Single Family Residence	No	Unknown	No
70420	904 S 9th	No	No	Unknown - Unlikely Lead	Don't know	1952	3/4"	Other	No	Other		Non-Lead - Copper	1952	3/4"	Other	Yes	Other	7/22/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No
70430	906 S 9th	No	No	Unknown - Unlikely Lead	Don't know	1992	3/4"	Installation date after lead ban	No	Other		Non-Lead - Copper	1992	3/4"	Installation date after lead ban	Yes	Other	7/22/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No
70450	1003 Crest	No	No	Unknown - Unlikely Lead	Don't know	No Date Found	1"	Other	No	Other		Non-Lead - Copper	No date found	1"	Other	Yes	Other	7/23/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No
70501	914 S 9th	No	No	Unknown - Unlikely Lead	Don't know	1910	3/4"	Other	No	Other		Non-Lead - Copper	1910	3/4"	Other	Yes	Other	8/30/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No
70520	918 S 9th	No	No	Unknown - Unlikely Lead	Don't know	1981	3/4"	Other	No	Other		Non-Lead - Copper	1981	3/4"	Other	Yes	Other	7/25/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No
70531	901 Big Horn Avenue	No	No	Unknown - Unlikely Lead	Don't know	1980	3/4"	Other	No	Other		Non-Lead - Copper	1980	3/4"	Other	Yes	Other	7/25/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No
70532	1009 West Road	No	No	Unknown - Unlikely Lead	Don't know	1980	3/4"	Other	No	Other		Non-Lead - Copper	1980	3/4"	Other	Yes	Other	8/1/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No
70533	1531 Big Horn Ave	No	No	Non-Lead - Plastic	Don't know	1996	3/4"	Installation date after lead ban	No	Other		Non-Lead - Plastic	1996	3/4"	Installation date after lead ban					Non-Lead		Single Family Residence	No	Unknown	No
70534	1011 West Road	No	No	Unknown - Unlikely Lead	Don't know	1917	3/4"	Other	No	Other		Non-Lead - Copper	1917	3/4"	Other	Yes	Other	8/1/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No
70535	815 Big Horn Ave	No	No	Non-Lead - Plastic	Don't know	1990	3/4"	Installation date after lead ban	No	Other		Non-Lead - Copper	1990	3/4"	Installation date after lead ban	Yes	Other	8/13/2024	Visual inspection at the inlet side of the meter- Copper Line	Non-Lead		Single Family Residence	No	Unknown	No
70540	809 Big Horn Ave	No	No	Unknown - Unlikely Lead	Don't know	1958	3/4"	Other	No	Other		Non-Lead - Copper	1958	3/4"	Other	Yes	Other	7/22/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No
70550	808 Big Horn	No	No	Unknown - Unlikely Lead	Don't know	1978	3/4"	Other	No	Other		Non-Lead - Copper	1978	3/4"	Other	Yes	Other	9/9/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No
70560	803 Big Horn	No	No	Unknown - Unlikely Lead	Don't know	1960	3/4"	Other	No	Other		Non-Lead - Copper	1960	3/4"	Other	Yes	Other	8/26/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No
70565	805 Big Horn Avenue	No	No	Non-Lead - Plastic	Don't know	2009	3/4"	Installation date after lead ban	No	Other		Non-Lead - Plastic	2009	3/4"	Installation date after lead ban	Yes	Other	8/26/2024	Visual inspection at the inlet side of the meter- Poly Line	Non-Lead		Single Family Residence	No	Unknown	No
70570	804 Big Horn	No	No	Unknown - Unlikely Lead	Don't know	1977	3/4"	Other	No	Other		Non-Lead - Copper	1977	3/4"	Other	Yes	Other	7/19/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No
70575	806 Big Horn	No	No	Non-Lead - Plastic	Don't know	2007	3/4"	Installation date after lead ban	No	Other		Non-Lead - Plastic	2007	3/4"	Installation date after lead ban	Yes	Other	8/8/2024	Visual inspection at the inlet side of the meter- Poly Line	Non-Lead		Single Family Residence	No	Unknown	No
70580	1010 Antelope	No	No	Unknown - Unlikely Lead	Don't know	1950	3/4"	Other	No	Other		Non-Lead - Copper	1950	3/4"	Other	Yes	Other	7/22/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No
70584	1344 Antelope	No	No	Non-Lead - Plastic	Don't know	2006	3/4"	Installation date after lead ban	No	Other		Non-Lead - Plastic	2006	3/4"	Installation date after lead ban	Yes	Other	8/21/2024	Visual inspection at the inlet side of the meter- Poly Line	Non-Lead		Single Family Residence	No	Unknown	No
70588	1366 Antelope	No	No	Non-Lead - Plastic	Don't know	1992	3/4"	Installation date after lead ban	No	Other		Non-Lead - Plastic	1992	3/4"	Installation date after lead ban	Yes	Other	8/21/2024	Visual inspection at the inlet side of the meter- Poly Line	Non-Lead		Single Family Residence	No	Unknown	No
70610	WY Retirement Center	No	No	Non-Lead - Other	Don't know	1980	6"	Other	No	Other		Non-Lead - Other	1980	6"	Service line diameter is > 2 inches	Yes	Other	10/1/2024	Visual inspection at the inlet-Cast iron. Outlet side-PVC	Non-Lead		Multiple Family Residence	No	Unknown	No
70650	1002 S 6th	No	No	Unknown - Unlikely Lead	Don't know	1977	3/4"	Other	No	Other		Non-Lead - Copper	1977	3/4"	Other	Yes	Other		Customer Verification on Water Line Survey	Unknown		Single Family Residence	No	Unknown	No
70655	703 Big Horn	No	No	Unknown - Unlikely Lead	Don't know	1920	3/4"	Other	No	Other		Non-Lead - Copper	1920	3/4"	Other	Yes	Other	7/18/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No
70660	603 Big Horn Ave	No	No	Unknown - Unlikely Lead	Don't know	1930	3/4"	Other	No	Other		Non-Lead - Copper	1930	3/4"	Other	Yes	Other	8/6/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No
70680	918 S 6th	No	No	Unknown - Unlikely Lead	Don't know	1978	3/4"	Other	No	Other		Non-Lead - Copper	1978	3/4"	Other	Yes	Other	9/1/2024	Customer Verification on Water Line Survey - Copper Line	Unknown		Single Family Residence	No	Unknown	No
70683	916 S 6th	No	No	Unknown - Unlikely Lead	Don't know	1930	3/4"	Other	No	Other		Non-Lead - Plastic	1930	3/4"	Other	Yes	Other	9/6/2024	Visual inspection at the inlet side of the meter- Poly Line	Unknown		Single Family Residence	No	Unknown	No

70685	820 S 6th	No	No	Non-Lead - Plastic	Don't know	1998	3/4"	Installation date after lead ban	No	Other	Non-Lead - Plastic	1998	3/4"	Installation date after lead ban	Yes	Other	7/18/2024	Visual Inspection at the inlet side of the meter- Poly Line	Non-Lead	Single Family Residence	No	Unknown	No	
70687	814 S 6th	No	No	Non-Lead - Plastic	Don't know	2003	3/4"	Installation date after lead ban	No	Other	Non-Lead - Plastic	2003	3/4"	Installation date after lead ban	Yes	Other	7/19/2024	Visual Inspection at the inlet side of the meter- Poly Line	Non-Lead	Single Family Residence	No	Unknown	No	
70688	810 S 6th	No	No	Non-Lead - Plastic	Don't know	2009	3/4"	Installation date after lead ban	No	Other	Non-Lead - Plastic	2009	3/4"	Installation date after lead ban	Yes	Other	7/23/2024	Visual Inspection at the inlet side of the meter- Poly Line	Non-Lead	Single Family Residence	No	Unknown	No	
70689	812 S 7th	No	No	Non-Lead - Plastic	Don't know	2005	3/4"	Installation date after lead ban	No	Other	Non-Lead - Plastic	2005	3/4"	Installation date after lead ban	Yes	Other	7/26/2024	Visual Inspection at the inlet side of the meter- Poly Line	Non-Lead	Single Family Residence	No	Unknown	No	
70690	810 S 7th	No	No	Non-Lead - Plastic	Don't know	2005	3/4"	Installation date after lead ban	No	Other	Non-Lead - Plastic	2005	3/4"	Installation date after lead ban	Yes	Other	7/23/2024	Visual Inspection at the inlet side of the meter- Poly Line	Non-Lead	Single Family Residence	No	Unknown	No	
70691	809 S 7th	No	No	Non-Lead - Plastic	Don't know	2007	3/4"	Installation date after lead ban	No	Other	Non-Lead - Plastic	2007	3/4"	Installation date after lead ban	Yes	Other	7/16/2024	Visual Inspection at the inlet side of the meter- Poly Line	Non-Lead	Single Family Residence	No	Unknown	No	
70692	819 S 7th	No	No	Non-Lead - Plastic	Don't know	2004	3/4"	Installation date after lead ban	No	Other	Non-Lead - Plastic	2004	3/4"	Installation date after lead ban	Yes	Other	8/12/2024	Visual Inspection at the inlet side of the meter- Poly Line	Non-Lead	Single Family Residence	No	Unknown	No	
70693	914 S 7th	No	No	Unknown - Unlikely Lead	Don't know	1984	3/4"	Other	No	Other	Non-Lead - Plastic	6/6/1905	3/4"	Other	Yes	Other	9/9/2024	Visual Inspection at the inlet side of the meter- Poly Line	Unknown	Single Family Residence	No	Unknown	No	
70694	815 S 7th	No	No	Non-Lead - Plastic	Don't know	2015	3/4"	Installation date after lead ban	No	Other	Non-Lead - Plastic	2015	3/4"	Installation date after lead ban	Yes	Other	8/7/2024	Visual Inspection at the inlet side of the meter- Poly Line	Non-Lead	Single Family Residence	No	Unknown	No	
70695	503 Big Horn	No	No	Non-Lead - Plastic	Don't know	1996	3/4"	Installation date after lead ban	No	Other	Non-Lead - Plastic	1996	3/4"	Installation date after lead ban	Yes	Other	7/18/2024	Visual Inspection at the inlet side of the meter- Poly Line	Non-Lead	Single Family Residence	No	Unknown	No	
70700	907 S 6th	No	No	Unknown - Unlikely Lead	Don't know	1980	3/4"	Other	No	Other	Non-Lead - Copper	1980	3/4"	Other	Yes	Other	7/18/2024	Visual Inspection at the inlet side of the meter- Copper Line	Unknown	Single Family Residence	No	Unknown	No	
70710	516 Matteson	No	No	Unknown - Unlikely Lead	Don't know	1978	3/4"	Other	No	Other	Non-Lead - Copper	1978	3/4"	Other	Yes	Other	8/20/2024	Visual Inspectio at the inlet side of the meter- Copper Line	Unknown	Single Family Residence	No	Unknown	No	
70720	902 S 5th	No	No	Unknown - Unlikely Lead	Don't know	1984	3/4"	Other	No	Other	Non-Lead - Copper	1984	3/4"	Other	Yes	Other	12/7/2023	Visual Inspection at the inlet side of the meter- Copper Line	Unknown	Single Family Residence	No	Unknown	No	
70730	904 S 5th	No	No	Unknown - Unlikely Lead	Don't know	1984	3/4"	Other	No	Other	Non-Lead - Copper	1984	3/4"	Other	Yes	Other	12/7/2023	Visual Inspection at the inlet side of the meter- Copper Line	Unknown	Single Family Residence	No	Unknown	No	
70740	906 S 5th	No	No	Unknown - Unlikely Lead	Don't know	1984	3/4"	Other	No	Other	Non-Lead - Copper	1984	3/4"	Other	Yes	Other	12/7/2023	Visual Inspection at the inlet side of the meter- Copper Line	Unknown	Single Family Residence	No	Unknown	No	
70750	908 S 5th	No	No	Unknown - Unlikely Lead	Don't know	1984	3/4"	Other	No	Other	Non-Lead - Copper	1984	3/4"	Other	Yes	Other	12/7/2023	Visual Inspection at the inlet side of the meter- Copper Line	Unknown	Single Family Residence	No	Unknown	No	
70760	910 S 5th	No	No	Unknown - Unlikely Lead	Don't know	1984	3/4"	Other	No	Other	Non-Lead - Copper	1984	3/4"	Other	Yes	Other	12/7/2023	Visual Inspection at the inlet side of the meter- Copper Line	Unknown	Single Family Residence	No	Unknown	No	
70770	912 S 5th	No	No	Unknown - Unlikely Lead	Don't know	1984	3/4"	Other	No	Other	Non-Lead - Copper	1984	3/4"	Other	Yes	Other	12/7/2023	Visual Inspection at the inlet side of the meter- Copper Line	Unknown					
70780	922 S 5th	No	No	Unknown - Unlikely Lead	Don't know	1984	3/4"	Other	No	Other	Non-Lead - Copper	1984	3/4"	Other	Yes	Other	12/7/2023	Visual Inspection at the inlet side of the meter- Copper Line	Unknown					
70785	924 S 5th	No	No	Unknown - Unlikely Lead	Don't know	1984	3/4"	Other	No	Other	Non-Lead - Copper	1984	3/4"	Other	Yes	Other	12/7/2023	Visual Inspection at the inlet side of the meter- Copper Line	Unknown					
70790	926 S 5th	No	No	Unknown - Unlikely Lead	Don't know	1984	3/4"	Other	No	Other	Non-Lead - Copper	1984	3/4"	Other	Yes	Other	12/7/2024	Visual Inspection at the inlet side of the meter- Copper Line	Unknown					
70800	928 S 5th	No	No	Unknown - Unlikely Lead	Don't know	1984	3/4"	Other	No	Other	Non-Lead - Copper	1984	3/4"	Other	Yes	Other	12/7/2023	Visual Inspection at the inlet side of the meter- Copper Line	Unknown					
70810	930 S 5th	No	No	Unknown - Unlikely Lead	Don't know	1984	3/4"	Other	No	Other	Non-Lead - Copper	1984	3/4"	Other	Yes	Other	12/7/2023	Visual Inspection at the inlet side of the meter- Copper Line	Unknown					
70820	932 S 5th	No	No	Unknown - Unlikely Lead	Don't know	1984	3/4"	Other	No	Other	Non-Lead - Copper	1984	3/4"	Other	Yes	Other	12/7/2023	Visual Inspection at the inlet side of the meter- Copper Line	Unknown					
70830	515 Matteson	No	No	Unknown - Unlikely Lead	Don't know	1971	3/4"	Other	No	Other	Non-Lead - Copper	1971	3/4"	Other	Yes	Other	7/17/2024	Visual Inspection at the inlet side of the meter- Copper Line	Unknown	Single Family Residence	No	Unknown	No	
70840	819 S 6th	No	No	Unknown - Unlikely Lead	Don't know	1972	3/4"	Other	No	Other	Non-Lead - Copper	1972	3/4"	Other	Yes	Other	8/9/2024	Visual Inspection at the inlet side of the meter- Copper Line	Unknown	Single Family Residence	No	Unknown	No	
70850	815 S 6th	No	No	Unknown - Unlikely Lead	Don't know	1976	3/4"	Other	No	Other	Non-Lead - Copper	1976	3/4"	Other	Yes	Other	8/21/2024	Visual Inspection at the inlet side of the meter- Copper Line	Unknown	Single Family Residence	No	Unknown	No	
70860	813 S 6th	No	No	Unknown - Unlikely Lead	Don't know	1976	3/4"	Other	No	Other	Non-Lead - Copper	1976	3/4"	Other	Yes	Other	7/19/2024	Visual Inspection at the inlet side of the meter- Copper Line	Unknown	Single Family Residence	No	Unknown	No	
70870	811 6th	No	No	Unknown - Unlikely Lead	Don't know	1972	3/4"	Other	No	Other	Non-Lead - Copper	1972	3/4"	Other	Yes	Other	7/18/2024	Visual Inspection at the inlet side of the meter- Copper Line	Unknown	Single Family Residence	No	Unknown	No	
70880	809 S 6th	No	No	Unknown - Unlikely Lead	Don't know	1977	3/4"	Other	No	Other	Non-Lead - Copper	1977	3/4"	Other	Yes	Other	7/18/2024	Visual Inspection at the inlet side of the meter- Copper Line	Unknown	Single Family Residence	No	Unknown	No	
70890	519 Holdredge	No	No	Unknown - Unlikely Lead	Don't know	1954	3/4"	Other	No	Other	Non-Lead - Copper	1954	3/4"	Other	Yes	Other	6/26/2024	Visual Inspection at the inlet side of the meter- Copper Line	Unknown	Single Family Residence	No	Unknown	No	
70900	505 Holdredge	No	No	Unknown - Unlikely Lead	Don't know	1953	3/4"	Other	No	Other	Non-Lead - Copper	1953	3/4"	Other	Yes	Other	9/5/2024	Visual Inspection at the inlet side of the meter- Copper Line	Unknown	Single Family Residence	No	Unknown	No	
70910	804 S 5th	No	No	Unknown - Unlikely Lead	Don't know	1953	3/4"	Other	No	Other	Non-Lead - Copper	1953	3/4"	Other	Yes	Other	7/24/2024	Visual Inspection at the inlet side of the meter- Copper Line	Unknown	Single Family Residence	No	Unknown	No	
70920	806 S 5th	No	No	Unknown - Unlikely Lead	Don't know	1953	3/4"	Other	No	Other	Non-Lead - Copper	1953	3/4"	Other	Yes	Other	7/22/2024	Visual Inspection at the inlet side of the meter- Copper Line	Unknown	Single Family Residence	No	Unknown	No	
70930	808 S 5th	No	No	Unknown - Unlikely Lead	Don't know	1953	3/4"	Other	No	Other	Non-Lead - Copper	1953	3/4"	Other	Yes	Other	2/1/2024	Visual Inspection at the inlet side of the meter- Copper Line	Unknown	Single Family Residence	No	Unknown	No	
70940	810 S 5th	No	No	Unknown - Unlikely Lead	Don't know	1954	3/4"	Other	No	Other	Non-Lead - Copper	1954	3/4"	Other	Yes	Other	7/17/2024	Visual Inspection at the inlet side of the meter- Copper Line	Unknown	Single Family Residence	No	Unknown	No	
70950	812 S 5th	No	No	Unknown - Unlikely Lead	Don't know	1953	3/4"	Other	No	Other	Non-Lead - Copper	1953	3/4"	Other	Yes	Other	7/25/2024	Visual Inspection at the inlet side of the meter- Copper Line	Unknown	Single Family Residence	No	Unknown	No	
70960	814 S 5th	No	No	Unknown - Unlikely Lead	Don't know	1953	3/4"	Other	No	Other	Non-Lead - Copper	1953	3/4"	Other	Yes	Other	7/16/2024	Visual Inspection at the inlet side of the meter- Copper Line	Unknown	Single Family Residence	No	Unknown	No	
70970	816 S 5th	No	No	Unknown - Unlikely Lead	Don't know	1953	3/4"	Other	No	Other	Non-Lead - Copper	1953	3/4	Other	Yes	Other	9/6/2024	Visual Inspection at the inlet side of the meter- Copper Line	Unknown	Single Family Residence	No	Unknown	No	
70980	818 S 5th	No	No	Unknown - Unlikely Lead	Don't know	1954	3/4"	Other	No	Other	Non-Lead - Copper	1954	3/4"	Other	Yes	Other	7/23/2024	Visual Inspection at the inlet side of the meter- Copper Line	Unknown	Single Family Residence	No	Unknown	No	
70990	820 S 5th	No	No	Unknown - Unlikely Lead	Don't know	1953	3/4"	Other	No	Other	Non-Lead - Copper	1953	3/4"	Other	Yes	Other	7/18/2024	Visual Inspection at the inlet side of the meter- Copper Line	Unknown	Single Family Residence	No	Unknown	No	
71000	509 Matteson	No	No	Unknown - Unlikely Lead	Don't know	1955	3/4"	Other	No	Other	Non-Lead - Copper	1955	3/4"	Other	Yes	Other	8/30/2024	Visual Inspection at the inlet side of the meter- Copper Line	Unknown	Single Family Residence	No	Unknown	No	
71010	806 S 6th	No	No	Unknown - Unlikely Lead	Don't know	1959	3/4"	Other	No	Other	Non-Lead - Copper	1959	3/4"	Other	Yes	Other	7/19/2024	Visual Inspection at the inlet side of the meter- Copper Line	Unknown	Single Family Residence	No	Unknown	No	1
71020	802 S 6th	No	No	Non-Lead - Plastic	Don't know	2009	3/4"	Installation date after lead ban	No	Other	Non-Lead - Plastic	2009	3/4"	Installation date after lead ban	Yes	Other	8/14/2024	Visual Inspection at the inlet side of the meter- Poly Line	Non-Lead	Single Family Residence	No	Unknown	No	
71030	603 Holdredge	No	No	Unknown - Unlikely Lead	Don't know	1980	3/4"	Other	No	Other	Non-Lead - Copper	1980	3/4"	Other	Yes	Other	8/5/2024	Visual Inspection at the inlet side of the meter- Copper Line	Unknown	Single Family Residence	No	Unknown	No	
71035	605 Holdredge	No	No	Unknown - Unlikely Lead	Don't know	1985	3/4"	Other	No	Other	Non-Lead - Copper	1985	3/4"	Other	Yes	Other	7/24/2024	Visual Inspection at the inlet side of the meter- Copper Line	Unknown	Single Family Residence	No	Unknown	No	
71040	805 S 7th	No	No	Unknown - Unlikely Lead	Don't know	1964	3/4"	Other	No	Other	Non-Lead - Copper	1964	3/4"	Other	Yes	Other	9/18/2024	Visual Inspection at the inlet meter-Copper Line	Unknown	Single Family Residence	No	Unknown	No	
71044	804 S 7th	No	No	Non-Lead - Plastic	Don't know	2006	3/4"	Installation date after lead ban	No	Other	Non-Lead - Plastic	2006	3/4"	Installation date after lead ban	Yes	Other	7/23/2024	Visual Inspection at the inlet side of the meter- Poly Line	Non-Lead	Single Family Residence	No	Unknown	No	
71045	802 S 7th	No	No	Non-Lead - Plastic	Don't know	1999	3/4"	Installation date after lead ban	No	Other	Non-Lead - Plastic	1999	3/4"	Installation date after lead ban	Yes	Other	7/19/2024	Visual Inspection at the inlet side of the meter- Poly Line	Non-Lead	Single Family Residence	No	Unknown	No	
71046	806 S 7th	No	No	Non-Lead - Plastic	No	2022	3/4"	Installation date after lead ban	No	Other	Non-Lead - Plastic	2022	3/4"	Installation date after lead ban					Non-Lead	Single Family Residence	No	Unknown	No	
71050	703 Holdredge	No	No	Unknown - Unlikely Lead	Don't know	1959	3/4"	Other	No	Other	Non-Lead - Copper	1959	3/4"	Other	Yes	Other	8/9/2024	Visual Inspection at the inlet side of the meter- Copper Line	Unknown	Single Family Residence	No	Unknown	No	
71060	705 Holdredge	No	No	Unknown - Unlikely Lead	Don't know	1959	3/4"	Other	No	Other	Non-Lead - Copper	1959	3/4"	Other	Yes	Other	7/18/2024	Visual Inspection at the inlet side of the meter- Copper Line	Unknown	Single Family Residence	No	Unknown	No	
71130	803 S 8th	No	No	Unknown - Unlikely Lead	Don't know	1953	3/4"	Other	No	Other	Non-Lead - Plastic	1953	3/4"	Other	Yes	Other	12/12/2023	Visual Inspection at the inlet side of the meter- Poly Line	Unknown	Single Family Residence	No	Unknown	No	
71150	802 S 8th	No	No	Unknown - Unlikely Lead	Don't know	1999	3/4"	Other	No	Other	Non-Lead - Plastic	1999	3/4"	Other	Yes	Other	7/23/2024	Visual Inspection at the inlet side of the meter- Poly Line	Unknown	Single Family Residence	No	Unknown	No	
90010	TOB			Unknown - Unlikely Lead							Unknown - Unlikely Lead								Unknown					
90011	TOB	No	No	Unknown - Unlikely Lead							Non-Lead - Other			Other	Yes	Other	1/23/2024	Visual Inspection--Cast Iron	Unknown	Building	No	Unknown	No	
90020	TOB	No	No	Unknown - Unlikely Lead							Non-Lead - Plastic	1980	3/4"	Other	Yes	Other	1/23/2023	Visual Inspection at the inlet side of the meter- Poly Line	Unknown	Building	No	Unknown	No	
90030	TOB	No	No	Unknown - Unlikely Lead							Non-Lead - Copper	1986	2"	Other	Yes	Other	12/12/2023	Visual Inspection at the inlet side of the meter- Poly Line	Unknown	Building	No	Unknown	No	
90040	TOB	No	No	Unknown - Unlikely Lead							Non-Lead - Copper		3/4"	Other	Yes	Other	1/23/2023	Visual Inspection at the inlet side of the meter- Copper Line	Unknown	Building	No	Unknown	No	
90050	TOB	No	No	Unknown - Unlikely Lead							Unknown - Unlikely Lead								Unknown					
90070	165 N 6th	No	No	Unknown - Unlikely Lead							Unknown - Unlikely Lead								Unknown					
90090	305 West B	No	No	Non-Lead - Copper	Don't know	1990	2"	Other	No	Other	Non-Lead - Copper	1990	2"	Other	Yes	Other	12/7/2023	Visual Inspection at the inlet side of the meter- Copper Line	Non-Lead	Building	No	Unknown	No	
90097	1212 West B	No	No	Non-Lead - Other	Don't know	2019	3"	Installation date after lead ban	No	Other	Non-Lead - Other	2019	3" Inlet Reduced to 2" at the meter	Service line diameter is > 2 inches	Yes	Other	8/20/2024	Visual Inspection at the inlet side of the meter- Ductile Iron	Non-Lead	Building	No	Unknown	No	
90098	1211 West B	No	No	Non-Lead - Other	Don't know	2019	3"	Installation date after lead ban	No	Other	Non-Lead - Other	2019	3" Inlet Reduced to 2" at the meter	Service line diameter is > 2 inches	Yes	Other	8/20/2024	Visual Inspection at the inlet side of the meter- Ductile Iron	Non-Lead	Building	No	Unknown	No	
201031	205 Montana			Unknown - Unlikely Lead							Unknown - Unlikely Lead								Unknown					
10075	760 N 7th	No	No	Unknown - Unlikely Lead	Don't know						Unknown - Unlikely Lead	1960							Unknown					
																		Visual Inspection at the						

10145	864 N 7th	No	No	Unknown - Unlikely Lead	Don't know								Non-Lead - Plastic	1984		Other	Yes	Other	10/3/2024	inlet side of the meter- Poly Line	Unknown						
10175	840 Highway 20	No	No	Unknown - Unlikely Lead	Don't know	1998	3/4"	Installation date after lead ban	No	Other			Non-Lead - Plastic	1998	3/4"	Installation date after lead ban					Unknown		Building	No	Unknown	No	
10280	957 N 8th	No	No	Non-Lead - Plastic	Don't know	2022		Installation date after lead ban					Non-Lead - Copper		3/4"	Installation date after lead ban				Water Project Completed in 2022.	Non-Lead						
10310	861 N 8th	No	No	Non-Lead - Plastic	Don't know	2022	3/4"	Installation date after lead ban	No	Other			Non-Lead - Plastic		3/4"	Installation date after lead ban				Water Project Completed in 2022.	Non-Lead		Single Family Residence	No	Unknown	No	
10340	857 N 8th	No	No	Non-Lead - Plastic	Don't know	2022	3/4"	Installation date after lead ban	No	Other			Non-Lead - Plastic		3/4"	Installation date after lead ban				Water Project Completed in 2022.	Non-Lead		Single Family Residence	No	Unknown	No	
10360	853 N 8th	No	No	Non-Lead - Plastic	Don't know	2022	3/4"	Installation date after lead ban	No	Other			Non-Lead - Plastic		3/4"	Installation date after lead ban				Water Project Completed in 2022.	Non-Lead		Single Family Residence	No	Unknown	No	
10400	759 N 8th	No	No	Non-Lead - Plastic	Don't know	2022	3/4"	Installation date after lead ban	No	Other			Non-Lead - Plastic		3/4"	Installation date after lead ban				Water Project Completed in 2022.	Non-Lead		Single Family Residence	No	Unknown	No	
10420	755 N 8th	No	No	Non-Lead - Plastic	Don't know	2022	3/4"	Installation date after lead ban	No	Other			Non-Lead - Plastic		3/4"	Installation date after lead ban				Water Project Completed in 2022.	Non-Lead		Single Family Residence	No	Unknown	No	
10440	751 N 8th	No	No	Non-Lead - Plastic	Don't know	2022	3/4"	Installation date after lead ban	No	Other			Non-Lead - Plastic		3/4"	Installation date after lead ban				Water Project Completed in 2022.	Non-Lead		Single Family Residence	No	Unknown	No	
10446	753 N 8th	No	No	Non-Lead - Plastic	Don't know	2022	3/4"	Installation date after lead ban	No	Other			Non-Lead - Plastic		3/4"	Installation date after lead ban				Water Project Completed in 2022.	Non-Lead		Single Family Residence	No	Unknown	No	
10450	752 N 8th	No	No	Non-Lead - Plastic	Don't know	2022	3/4"	Installation date after lead ban	No	Other			Non-Lead - Plastic		3/4"	Installation date after lead ban				Water Project Completed in 2022.	Non-Lead		Single Family Residence	No	Unknown	No	
10509	762 N 8th	No	No	Non-Lead - Plastic	Don't know	2022	3/4"	Installation date after lead ban	No	Other			Non-Lead - Plastic		3/4"	Installation date after lead ban				Water Project Completed in 2022.	Non-Lead		Single Family Residence	No	Unknown	No	
10511	920 N 8th	No	No	Non-Lead - Plastic	Don't know	2022	3/4"	Installation date after lead ban	No	Other			Non-Lead - Plastic		3/4"	Installation date after lead ban				Water Project Completed in 2022.	Non-Lead		Single Family Residence	No	Unknown	No	
10513	960 N 8th	No	No	Non-Lead - Plastic	Don't know	2022	3/4"	Installation date after lead ban	No	Other			Non-Lead - Plastic		3/4"	Installation date after lead ban				Water Project Completed in 2022.	Non-Lead		Single Family Residence	No	Unknown	No	
10514	952 N 8th	No	No	Non-Lead - Plastic	Don't know	2022	3/4"	Installation date after lead ban	No	Other			Non-Lead - Plastic		3/4"	Installation date after lead ban				Water Project Completed in 2022.	Non-Lead		Single Family Residence	No	Unknown	No	
10514.8	954 N 8th	No	No	Non-Lead - Plastic	Don't know	2022	3/4"	Installation date after lead ban	No	Other			Non-Lead - Plastic		3/4"	Installation date after lead ban				Water Project Completed in 2022.	Non-Lead		Single Family Residence	No	Unknown	No	
10515	956 N 8th	No	No	Non-Lead - Plastic	Don't know	2022	3/4"	Installation date after lead ban	No	Other			Non-Lead - Copper		3/4"	Installation date after lead ban				Water Project Completed in 2022.	Non-Lead		Single Family Residence	No	Unknown	No	
10516	958 N 8th	No	No	Non-Lead - Plastic	Don't know	2022	3/4"	Installation date after lead ban	No	Other			Non-Lead - Copper		3/4"	Installation date after lead ban				Water Project Completed in 2022.	Non-Lead		Single Family Residence	No	Unknown	No	
10540	4125 Golf Course Road	No	No	Non-Lead - Plastic	Don't know	1998	3/4"	Installation date after lead ban	No	Other			Non-Lead - Plastic	1998	3/4"	Installation date after lead ban				Attached to SBHC Water District Line. Lines installed 1998 and later	Non-Lead		Single Family Residence	No	Unknown	No	
10870	453 N 8th	No	No	Unknown - Unlikely Lead	Don't know	1920							Unknown - Unlikely Lead								Unknown						
10940	658 N 7th	No	No	Unknown - Unlikely Lead	Don't know	1910							Unknown - Unlikely Lead								Unknown						
11020	660 N 6th	No	No	Unknown - Unlikely Lead	Don't know	1969							Unknown - Unlikely Lead								Unknown						
11050	462 N 5th	No	No	Unknown - Unlikely Lead	Don't know	1920	3/4"	Other	No	Other			Non-Lead - Copper	1920	3/4"	Other	Yes	Other	10/1/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No	
11055	408 West G	No	No	Unknown - Unlikely Lead	Don't know	1946	3/4"	Other	No	Other			Non-Lead - Copper	1946	3/4"	Other	Yes	Other	9/20/2024	Visual inspection at the inlet side of the meter- Copper Line	Unknown		Single Family Residence	No	Unknown	No	
11170	851 N 6th	No	No	Unknown - Unlikely Lead	Don't know	2022	3/4"	Installation date after lead ban	No	Other			Non-Lead - Plastic	2022	3/4"	Installation date after lead ban					Unknown		Single Family Residence	No	Unknown	No	
20350	257 N 8th	No	No	Unknown - Unlikely Lead	Don't know	1952							Unknown - Unlikely Lead								Unknown						
20380	618 West E	No	No	Non-Lead - Plastic	Don't know	1994	3/4"	Service line repair or replacement record	No			Records from the Myrtle & N 7th Street Water Line Replacement 1994	Non-Lead - Copper	1900	3/4"	Other	Yes	Other	9/23/2024	Visual inspection at the inlet side of the meter- Copper Line	Non-Lead		Single Family Residence	No	Unknown	No	
10155	717 West Hart	No	No	Unknown - Unlikely Lead	Don't know	1986															Unknown						
71047	808 S 7th	No	No	Non-Lead - Plastic	Don't know	2024	3/4"	Installation date after lead ban	No	Other			Non-Lead - Plastic	2024	3/4"	Installation date after lead ban	Yes	Other	9/26/2024	TCB Installed a new tap from main water line on s 7th Street. Main Line is PVC. Service line is poly to the meter pit. Customer will connect on the outlet side of pit with poly pipe.	Non-Lead		Single Family Residence	No	Unknown	No	
No Account number	Mailing address: 906 S 9th. Physical property is inbetween 415 & 417 West C Street	No	No	Non-Lead - Plastic	Don't know	1990	3/4"	Service line repair or replacement record	No		9/1/2024	Mechanical Excavation to install meter pit. Service line is Copper with poly attached to the meter pit. Non lead compression fitting used.															